

Evaluation of System Reliability of  
Guru Nanak Dev Thermal Plant, Bhatinda

A THESIS

Submitted in partial Fulfilment of the  
requirements for the degree of

MASTER OF ENGINEERING  
(MECHANICAL)

in

HEAT POWER ENGINEERING


of

PUNJABI UNIVERSITY, PATIALA

90207  
10.1.99 1326

By

SATISH KUMAR



Under the guidance of

Dr. R. C. BAHL

Associate Professor

DEPARTMENT OF MECHANICAL ENGINEERING

THAPAR COLLEGE OF ENGINEERING

PATIALA

Dec., 1981


(1)

CERTIFICATE


Certified that the thesis entitled "EVALUATION OF SYSTEM RELIABILITY OF GURU NANAKDEV THERMAL PLANT, BHATINDA" which is being submitted by Er. Satish.kumar, in partial fulfilment of the requirements for the award of the degree of MASTER OF ENGINEERING-MECHANICAL (HEAT POWER ENGINEERING) of Punjabi University, Patiala is a record of student's own work carried out under my supervision and guidance. The matter embodied in this thesis has not been submitted to any University or Institution for the award of any degree or diploma.

The thesis has reached the standard fulfilling the requirements of the regulations for the award of the said work.


Dated: Dec 23, 1981  
Patiala.

  
( Dr. R.C. BAHL )  
Thesis Supervisor

Countersigned.

  
(Dr. GAJENDRA SINGH)

PROFESSOR & HEAD,  
MECHANICAL ENGINEERING DEPT.,  
THAPAR COLLEGE OF ENGINEERING,  
PATIALA-147001.

  
PROF. P.V. GUPTA  
DEAN,  
FACULTY OF ENGINEERING  
& TECHNOLOGY,  
PUNJABI UNIVERSITY, PATIALA.

ACKNOWLEDGEMENTS

The author expresses his sincere and profound gratitude to Dr. R.C. Bahl, Associate Professor, Department of Mechanical Engineering, Thapar College of Engineering, Patiala for his guidance and critical review of this work.

The author is grateful to the Engineers of the Thermal Design Directorate, Patiala and Guru Nanak Dev Thermal Plant, Bhatinda for their kind cooperation at all stages of this work and in making available the necessary data. The author is thankful to Sh. Nand Lal, for the neat and clean type work.

Finally, the author wishes to place on record his sense of appreciation for his wife Dr. Meenakshi for her cooperation, patience and above all the inspiration throughout this work.

Dated: Dec. 23, 1981.

*Satish Kumar.*  
( SATISH KUMAR )

ABSTRACT

In this work, system reliability of unit I of the existing 4x110 M.W. Units of G.N.D. Thermal Plant, Bhatinda has been evaluated. The working of the unit for the period from 1.1.77, 00 Hrs to 17.10.78, 16.40 Hrs was considered for the said purpose. The data so obtained was used in the evaluation of system reliability.

The work is based on the criterion that the unit is performing adequately well or satisfactorily so long as it is delivering power, may be at the rated or derated levels.

Various types of failures resulting in system breakdown have been studied and accordingly various components/Sub-systems and their break down times have been sorted out. The Sub-system-System relationship on functional basis is studied and a "Reliability Block Diagram" of the system is developed. The reliability of various components/Sub-systems have been worked out and commented upon. Based on the values of individual component/Sub-system reliability, system reliability of the unit has been worked out.

From the computed values of individual component reliability, the main boiler is established to be the weakest link in the thermal power plant system.



TABLE OF CONTENTS

|   | <u>PAGE</u> |
|---|-------------|
| CERTIFICATE   | i           |
| ACKNOWLEDGEMENTS                                    | ii          |
| ABSTRACT  | iii         |
| TABLE OF CONTENTS                                   | iv          |
| LIST OF FIGURES                                     | vi          |
| NOMENCLATURE  | vii         |
| 1 PREVIEW   | 1           |
| 1.1 Introduction                                    | 1           |
| 1.2 Literature Review                               | 5           |
| 1.2.1 History of Reliability Studies                | 5           |
| 1.2.2 Background to Reliability                     | 8           |
| 1.2.3 Reliability Parameters                        | 9           |
| 1.2.4 Analytical Methods to Determine Reliability   | 11          |
| 1.2.4.1 Introduction                                | 12          |
| 1.2.4.2 The Probability Density Function<br>Method  | 13          |
| 1.2.4.3 Weibull Function Method                     | 14          |
| 1.2.5 SYSTEMS CONFIGURATION                         | 15          |
| 1.2.5.1 Series Configuration                        | 15          |
| 1.2.5.2 Parallel Configuration                      | 16          |
| 1.2.5.3 Combined Series - Parallel<br>Configuration | 17          |
| 2 FORMULATION OF THE PROBLEM                        | 19          |
| 2.1 Performance Criterion                           | 19          |
| 2.2 Problem   | 19          |

|  | <u>PAGE</u> |
|--|-------------|
| 2.3 Data   | 20          |
| 2.4 Solution Technique                                   | 20          |
| 2.4.1 Determination of Component &<br>System Reliability | 20          |
| 3. CALCULATIONS AND RESULTS                              | 58          |
| 3.1 Calculations for Component Reliability               | 58          |
| 3.2 Calculations for System Reliability                  | 59          |
| 3.2.1 Assumptions  | 59          |
| 3.2.2 System Reliability                                 | 60          |
| 4. DISCUSSION OF RESULTS AND CONCLUSIONS                 | 61          |
| 5. SCOPE FOR FURTHER WORK                                | 62          |
| REFERENCES   | 63          |
| FIGURES  | 64          |
| APPENDICES   | 74          |



|             | <u>LIST OF FIGURES</u>                                  | <u>PAGE</u> |
|-------------|---|-------------|
| 1.          | BATH TUB CURVE; FAILURE RATE VERSUS AGE                 | 64          |
| 2.          | PROBABILITY DENSITY FUNCTION                            | 65          |
| 3.          | THEORETICAL NON-REPLACEMENT TEST                        | 66          |
| 4.(A,B)     | SERIES RELIABILITY CONFIGURATION                        | 67          |
| 5.(A,B)     | PARALLEL RELIABILITY CONFIGURATION                      | 68          |
| 6.(A,B)     | COMBINED SERIES-PARALLEL CONFIGURATION                  | 69          |
| 7.          | FUNCTIONAL BLOCK DIAGRAM                                | 70          |
| 8.(A,B,C,D) | RELIABILITY BLOCK DIAGRAM OF THE<br>VARIOUS SUB-SYSTEMS | 71          |
| 9.          | RELIABILITY BLOCK DIAGRAM OF BOILER<br>AUXILIARIES      | 72          |
| 10.         | RELIABILITY BLOCK DIAGRAM OF THE SYSTEM                 | 73          |



NOMENCLATURE

| <u>Symbol</u> | <u>Explanation</u>                  |
|---------------|-------------------------------------|
| $R_{F.O}$     | Reliability of Fuel-Oil System      |
| $R_{B.A}$     | Reliability of Boiler Auxillaries   |
| $R_{M.B}$     | Reliability of Main Boiler          |
| $R_{T.A}$     | Reliability of Turbine Auxillaries  |
| $R_T$         | Reliability of Turbine              |
| $R_{G/E}$     | Reliability of Generator/Exciter    |
| $R_{E.E}$     | Reliability of Electrical Equipment |
| $R_{I/C}$     | Reliability of Instruments/Controls |
| $R_S$         | Reliability of System               |
| $R_{S_1}$     | Reliability of Sub-system 1         |
| $R_{S_2}$     | Reliability of Sub-system 2         |
| $R_{S_3}$     | Reliability of Sub-system 3         |
| $R_{S_4}$     | Reliability of Sub-system 4         |
| $R_1$         | Reliability of Induced draft Fan 1  |
| $R_2$         | Reliability of Induced draft Fan 2  |
| $R_3$         | Reliability of Forced draft Fan 1   |
| $R_4$         | Reliability of Forced draft Fan 2   |
| $R_5$         | Reliability of other components     |



1. PREVIEW

1.1 INTRODUCTION

The trend in the modern technology is to intensify the use of the plant and machinery. Production rates have increased and at the same time, due to extended operation, the opportunities for maintenance are reduced. In continuous or semicontinuous industrial process or flow-line production, the failure of a unit due to continuous deterioration or catastrophic failure is costly and sometimes dangerous. If some preventive measures are adopted, the failure can be reduced to a large extent if not completely avoided/eliminated.

In recent times, the development of complex systems has tremendously expanded man's capabilities but it has also increased the maintenance requirements. Huge amount of money is being spent on maintenance of complex systems. In 1975, United States Electric Utilities spent over \$ 3 billion for maintenance. This represented more than 100 percent increase in five years. Almost \$ 2 billion was for the maintenance of generating plant. In addition to these direct out-of-pocket costs, hidden costs are generally incurred when the system is unavailable.

The maintenance decisions largely depend on uncertain behaviour of equipment such as it is rather difficult to predict with certainty the occurrence of failure or more generally the instant of transition from good state of the equipment to its failed state. A further source of uncertainty stems out from the problems associated with determination of the state of the equipment; good, failed or in-between, unless a definite maintenance action such as inspection is taken. It is therefore, essential that the foundations of "maintainability" and "reliability" are laid at the earliest stages of design so as to avoid/or reduce the failure of the equipment.

Reliability is a relatively new field whose conception is primarily due to complexity, sophistication, & automation inherent in modern technology. The approach used in reliability work varies with the individual and the organisation. In a field as young as this, few established schools of thought or doctrines are prevalent. Thus, the mathematician faced with a reliability problem often treats it as an exercise in applied probability or statistics. A manager attempts to organise a reliability group, which often turns out to be a staff organisation. The quality-control expert views reliability as an extension of his efforts. The component engineer tries to buy the best and most reliable parts. The system engineer looks for an inherently simple scheme which will lead to a reliable design.

In actuality no single approach is satisfactory, and the problem must be approached at all levels and at each step of the industrial process. Thus, reliability is essentially a birth-to-death problem, involving such areas as raw material and parts quality, conceptual design, detailed engineering design, production, test and quality control, product shipment, warehouse storage, operator skill and technique, maintenance, and product use.

It is apparant from the above discussion that reliability technique is a tool to study the reliability analysis, reliability design & reliability improvement of complex systems in modern technology. The present study deals with the reliability determination of an existing thermal power plant that is in operation.

The basic aim of reliability engineering/study is to increase the reliability of the system. The most important methods for doing this are:

- a) Reduce the complexity of the system to the minimum essential for the required operation. Nonessential components and unnecessary complex configurations only increase the probabilities of system failure.
- b) Increase the reliability of the components in the system.
- c) Parallel redundancy: One or more("hot") spares operate in parallel. If one fails, others still function.
- d) Stand by redundancy: A("cold) spare is switched in to take over the function of a component or subsystem that has failed.

e) Repair maintenance: Failed components are replaced by a technician rather than switched in as in (d). Replacement is neither automatic nor necessarily immediate.

f) Preventive maintenance: Components are replaced by new ones periodically even though they may not have failed by the time of replacement.

Methods (a) & (b) are obviously limited by the current state of technology. The other four methods enable, in principle, to develop systems having reliabilities which approach 100-percent for all arbitrarily chosen mission times. It is not always feasible to do this in view of constraints such as limits on weight, space, cost, or maintainability & availability. Another task of reliability engineering is to maximise system reliability for a given weight, size, cost or other constraints for a given reliability.

Author's interest in the problem is motivated by drastic power cuts enforced in the recent past and continuously deteriorating condition of power supply in the State of Punjab. The heavy load shedding has caused much discontent & inconvenience to the general public, farmers & industrialists alike. Besides this, the State Board and the State Govt. has lost a big chunk of its revenue on account of closure of factories. Thus, the overall impact of load shedding has proved to be a big leap backward in the progress/industrialisation of the State.

The plant under study is one of the units of 4x110MW Guru Nanak Dev Thermal Plant, Bhatinda(Punjab) owned & operated

by Punjab State Electricity Board. All the four units are of M/S Bharat Heavy Electricals Limited make & are identical in design. The units are coal based with oil firing at part-load operation and/or for flame stabilisation.

The break down data of unit I for the period from 1st Jan, 1977 00.00 Hrs. up to 18.10.78 16.40 Hrs. (After this the unit was released for capital maintenance) was collected. The breakdown period for the respective elements was identified & total breakdown time for the respective elements calculated. Reliability of each element was computed thereafter.

Various elements and their grouping in the system was studied and analysed on functional basis. Reliability of the system is then computed from the system-element relationship.

The present study deals with computing the reliability of unit I only and that too under various simplifying assumptions. The assumptions have been brought out in relevant sections.

## 1.2 LITERATURE REVIEW

### 1.2.1 HISTORY OF RELIABILITY STUDIES

Reliability was first recognized as a pressing need during World War II. The problems of maintenance, repair, and field failures became severe for the military equipment used in World War II. The preliminary steps taken were to establish joint Army & Navy parts standards and to set up the Vacuum

Tube Development Committee in June, 1943. At the close of the war, between 1945 & 1950, several studies revealed some startling results:

(i) A Navy study made during maneuvers showed that the electronic equipment was operative only 30 percent of the time.

(ii) An Army study revealed that between two-thirds and three-fourths of their equipment was out of commission or under repairs.

(iii) An Air Force study conducted over a 5-year period disclosed that repair and maintenance costs were about 10 times the original cost.

(iv) A study uncovered the fact that for every tube in use there were one on the shelf and seven in transit.

(v) Approximately one electronics technician was required for every 250 tubes.

(vi) In 1937 a destroyer had 60 tubes; in 1952 the number had risen to 3,200.

These findings served as an impetus for further investigations.

One focal point of trouble appeared to be the vacuum tube. Following the vacuum tube development committee, an & airlines group set up a study in 1946 aimed at development of better electronics tubes. This was followed by parallel studies conducted by Aeronautical Radio, Inc. and Cornell University, in which, respectively, 45,000 and 100,000 defective tubes were examined. Between 1949 & 1953 Vitro Laboratories

and Bell Laboratories pursued similar studies on the failure of parts other than vacuum tubes, such as resistors, capacitors, transformers, relays, etc. In 1950 the Department of Defence established an adhoc committee on reliability, which in 1952 became a permanent group called the Advisory Group on the Reliability of Electronic Equipment (AGREE). An AGREE report was published in 1957, which was shortly followed by a specification on the reliability of military electronic equipment.

Since the mid-1950s much work has been done on reliability analysis. The titles reliability engineer and reliability group have been born. Several texts have appeared on the subject of reliability, and College and industrial courses on reliability have been initiated. Many bibliographies have been published in various sources. NASA currently publishes a monthly digest entitled Reliability Abstracts & Technical Reviews, containing about 50 one-page reviews. Research results are printed in <sup>n</sup>many different journals and presented at a large number of conferences. Three research publications of particular interest are The IEEE Transactions on Reliability, The Proceedings of the Annual Symposium on Reliability, a symposium sponsored by the IEEE and the ASQC, and The Proceedings of the Annual Reliability and Maintainability Conference, sponsored by the SAE, ASME, and AIAA.

1.2.2

BACKGROUND TO RELIABILITY

Safety of a thermal power generating system depends on reliability of individual components which plays a particularly important role especially when the reserve capacity is nil. Reliability is relatively new field whose conception is primarily due to complexity, sophistication, and automation inherent in a thermal power generating system.

Smith (1) has described reliability as the probability that a given system or device will operate for a given period of time, without failure, and under given operating conditions. Smith (4) has described reliability as a measure of the capacity of a piece of equipment to operate without failure when put in to service. National Aeronautics and Space Administration (NASA) has defined reliability as the probability of a device performing adequately for the period of time intended under the operating conditions encountered. Reliability is always a probability associated with a no-failure performance of a device (up to and including a large system) after an accumulated time ( can be a very short or a very long period) in a specific environment over a given period of operation with some desired level of confidence. Reliability is, therefore, the probability that a given system will perform as anticipated. In a rather real sense, anything which is reliable is, by definition, well made. Shooman (3) has described that reliability leans heavily on probability for its underlying support. He has emphasized the need of a good working knowledge of probability theory

for any real appreciation of reliability. Haviland (5) has described reliability as the mathematical probability that a device will operate as required. Reliability, thus leans heavily for its underlying support on applied mathematics.

Since failure and non-failure are mutually exclusive events, and there is a probability of unity that one or the other must occur, then the sum of these two probabilities also must be unity. If the reliability to time  $t$  is  $R(t)$  and the unreliability to time  $t$  is  $Q(t)$ , then, from the above,

$$R(t) + Q(t) = 1 \quad \text{-- (1)}$$

Gupta and Kapoor (2) has described statistical or empirical probability as, if in  $n$  trials, an event  $E$  happens  $m$  times, then the probability "p" of the happening of  $E$  is given by

$$p = P(E) = \lim_{n \rightarrow \infty} \frac{m}{n} \quad \text{-- (2)}$$

Applying this to reliability, let there be  $N_0$  articles put on test and allowed to fail without replacement so that at any time  $t$  there are  $N_s(t)$  surviving and  $N_f(t)$  failed. Then

$$N_s(t) + N_f(t) = N_0 \quad \text{-- (3)}$$

If the reliability,  $R(t)$ , of these articles is the probability of nonfailure in time  $t$ , then, by the above definition of probability,

$$R(t) = N_s(t) / N_0 \quad \text{-- (4)}$$

### 1.2.3 RELIABILITY PARAMETERS

Reliability is essentially a study of the causes, distribution & prediction of failure. Smith (1) has defined

failure as the termination of the ability of an item to perform its required function. To derive the basic reliability parameter of failure rate,  $\lambda(t)$  i.e. the rate of change of the no. of failures, it is imperative to observe and measure the relationship which exists between failure and time. Occurrence of failures are also defined as the mean time between successive failures or meantime between failures (M.T.B.F). Mean time to fail (M.T.T.F) is defined as the mean operating time between successive failures.

Empirically,  $M.T.T.F. + \text{Mean time to repair} = M.T.B.F.$

Consider a population of homogenous components from which a very large sample is taken and placed in operation at time  $T=0$ . The population initially shows a high failure rate. This decreases rather rapidly as shown in Figure 1, which is known as a bath-tub curve due to its shape. Shooman (3) has described high failure rates early in the life time of equipment due to initial weakness of defects, poor insulation, weak parts, bad assembly, poor fits etc. During the middle period of equipment operation fewer failures takes place, but it is difficult to determine their cause. In general, they seem to occur when the environmental stresses exceed the design strengths of the part or equipment. It is difficult to predict the environmental-stress amplitude or the part strengths as deterministic functions of time; thus the middle-life failures or constant failure rates are often called random failure or useful life period.

As the item reaches old age, things begin to deteriorate, and many failures occur. This failure region is called the wearout region. The bath-tub curve (Fig.1) with a period of early failures, a useful life (constant failure rate), and a wearout period, applies to most electronic components. Electromechanical & mechanical devices, on the other hand, have no period of constant failure rate since the wearout mechanism is present from the beginning of the life of the device. Such variable-failures are distributed according to the Weibull function. Smith (1) has described that if a population exhibits random failures, it may be treated as having a constant failure rate for the population as a whole. Failure rates are expressed either as so many percent per 1000 h or as so many failures per hour. Constant failure rate is calculated as the number of failures divided by the number of component-hours accumulated.

Smith (1) has described components in the range of failure rates  $10^{-5}$  to  $10^{-7}$  per hour exhibit current commercial reliability levels. A component with failure rate of the order of  $10^{-8}$  per hour is considered highly reliable; one with a failure rate of  $10^{-9}$  per hour is considered particularly reliable and would normally be encountered in special-purpose components.

#### 1.2.4 ANALYTICAL METHODS TO DETERMINE RELIABILITY

In performing the reliability analysis of a complex system, Shooman (3) has described that the logical

approach is to decompose the system into functional entities composed of units, subsystems, or components. Each entity is assumed to have two states, one good and one bad. The subdivision generates a block diagram description of system operation. Models are then formulated to fit this logical structure, and the calculus of probability is used to compute the system reliability in terms of sub-division reliabilities. Series and parallel structure often occur, and their reliability can be described very simply. In many cases the structure is of a more complicated nature, and more general techniques are needed. The formulation of a structural-reliability model can be difficult in a large, sophisticated system and requires much approximation and judgement.

Therefore, in order to predict the reliability of a system it is necessary to know the reliability of its element/component parts. To determine component reliability the failure rate (or Weibull parameters in the case of Variable failure rates) must be ascertained for each component. An attempt has been made to justify the methodology adopted for determining analytically reliability of the constituent components.

#### 1.2.4.1 INTRODUCTION

The bath-tub curve (Figure 1) with a period of early failures, a useful life (constant failure rate), and a wearout period, applies to most electronic components

(excluding relays & thermionic relays). Electro-mechanical & mechanical devices, on the other hand, have no period of constant failure rate since the wear out mechanism is present from the beginning of the life of the device. Smith (1) has described that variable failure rates are obtained when constant failure-rate devices are used together in redundant configuration. If variable-failure-rate components are replaced as they fail, eventually a population of homogenous components will evolve such that all the components have different "starting points". Such a population will exhibit random failures and may be treated as having a constant failure rate.

1.2.4.2 THE PROBABILITY DENSITY FUNCTION METHOD

Figure 2 represents the general case of failure probability density function  $f(t)$  plotted against time. Consider the possibility of failure in the interval from  $t$  to  $t+dt$ . The failure probability density function is such that the probability of failure in the time interval from  $t$  to  $t + dt$  is  $dt f(t)$ . The area of the shaded strip is  $dt f(t)$  and is therefore the probability of failure in the time interval represented by that strip ( $t$  to  $t + dt$ ). It follows that the probability of failure in the interval  $t_1$  to  $t_2$  is  $\int_{t_1}^{t_2} f(t) dt$ .

For the constant-failure rate case,

$$f(t) = \lambda \cdot e^{-t} \quad \text{--(5) (SEE APPENDIX I \& II)}$$

Not constraining to the constant-failure-rate case,

$$\lambda(t) = \frac{dR(t)}{R(t) dt} \quad \text{--(6) SEE APPENDIX II}$$

This is a general expression for failure rate

in terms of reliability and is useful when failure rate cannot be derived from mean time before failure (M T B F) except when failure rate is constant.

1.2.4.3 WEIBULL FUNCTION METHOD

Electromechanical and mechanical devices have no period of constant failure rate since the wear out mechanism is present from the beginning of the life of the device.

$$\text{We know that } R(t) = \exp \left[ - \int_0^t \lambda(t) dt \right]$$

Since the relationship of  $\lambda(t)$  to time depends on the device in question, the integral cannot be evaluated for the general case. Even if the variation of failure rate with time was known, it might well be of such a complex nature that the evaluation of the integral would prove far from simple. In practice the variation of failure rate with time is often such that the reliability function takes the form

$$R(t) = \exp \left[ - \left( \frac{t - \gamma}{\eta} \right)^\beta \right] \quad \text{--(7) SEE APPENDIX III}$$

Such failure's are said to be distributed according to the Weibull function.

Variable-failure-rates are obtained when constant-failure-rates devices are used together in redundant configuration. In a population of homogenous components, each individual component has a varying failure rate, and if large no's of components are replaced at the same time, then the assumption of constant-failure-rate no longer holds good.

1.2.5 SYSTEM CONFIGURATION

1.2.5.1 SERIES CONFIGURATION

The simplest and perhaps most common structure in reliability analysis is the series configuration. In the series case the functional operation of the system depends on the proper operation of all system components. A series reliability configuration will be portrayed by the block-diagram representation shown in Fig. 4 (A), or the reliability graph shown in Fig. 4 (B). In either case, a single path from cause to effect is created. Failure of any component is represented by removal of the component, which interrupts the path and thereby causes the system to fail.

The system shown in Fig. 4 is divided in to n series-connected units. The event signifying the success of the nth unit will be  $x_n$ , and  $\bar{x}_n$  will represent the failure of the nth unit. The probability that unit n is successful will be  $R(x_n)$ , and the probability that unit n fails will be  $Q(\bar{x}_n)$ . The probability of system success is denoted by  $R_s$ . In keeping with the definition of reliability in section 1.2.2, the probability of system failure is

$$Q_s = 1 - R_s$$

Since the series configuration requires that all units operate successfully for system success, the event representing system success is the intersection of  $x_1, x_2, \dots, x_n$ . The probability of this event is given by

$$R_s = R(x_1 x_2 x_3 \dots x_n) \quad (8)$$

Expansion of Equation (8) yields

$$R_s = R(x_1) R(x_2/x_1) R(x_3/x_1 x_2) \dots R(x_n/x_1 x_2 \dots x_{n-1}) \quad (9)$$

The expression appearing in Equation (9) contains probabilities, which must be evaluated with care. If the units do not interact, the failures are independent, and Equation (9) simplifies to

$$R_s = R(x_1) R(x_2) R(x_3) \dots R(x_n) \quad (10)$$

An alternative approach is to compute the probability of failure.

The reliability of a series system is always worse than the poorest component and is generally a disappointment from a reliability stand-point.

#### 1.2.5.2 PARALLEL CONFIGURATION

In many systems several signal paths perform the same operation. If the system configuration is such that failure of one or more paths still allows the remaining path or paths to perform properly, the system can be represented by a parallel model.

A block diagram and reliability graph for a parallel system are shown in Fig. 5. There are  $n$  paths connecting input to output, and all units must fail in order to interrupt all the paths. This is some times called a redundant configuration. Thus, a parallel model may occur as a result of the basic system structure or may be produced by using redundancy in a reliability design or redesign of the system.

In a parallel configuration the system is successful if any one of the parallel channels is successful. The probability of success is given by the probability of the union of the n successful events

$$R_s = R(x_1 + x_2 + x_3 + \dots + x_n) \quad (11)$$

System failure occurs if all the system units fail, yielding the probability of their intersection.

$$Q_s = Q(\bar{x}_1 \bar{x}_2 \bar{x}_3 \dots \bar{x}_n) \quad (12)$$

$$\text{Where } R_s = 1 - Q_s$$

Substitution of Equation (11) into Equation (12) and expansion yields

$$R_s = 1 - R(\bar{x}_1) R(\bar{x}_2/\bar{x}_1) R(\bar{x}_3/\bar{x}_1 \bar{x}_2) \dots R(\bar{x}_n/\bar{x}_1 \bar{x}_2 \dots \bar{x}_{n-1}) \quad (13)$$

If the unit failures are independent, Equation (13) simplifies to

$$R_s = 1 - R(\bar{x}_1) R(\bar{x}_2) \dots R(\bar{x}_n) \quad (14)$$

### 1.2.5.3 COMBINED SERIES - PARALLEL CONFIGURATION

Any complete system generally consists of a large number of components or units in series. If any one component or unit fails, the system fails. In many cases, the less reliable components in a system are backed by parallel components to increase system reliability by parallel redundancy. Sometimes a whole group of components is backed by an equal or similar group operating in parallel with the first group. These parallel arrangements of two or more groups can be considered as single units in series within

the system. If such a unit fails as a whole, the system fails.

From the foregoing, it follows that combinations of series and parallel reliability are common, and system reliability is computed using rules of sections 1.2.5.1 & 1.2.5.2

Series parallel and parallel-series reliability configurations are illustrated by the block-diagram representations shown in Figs. 6 (A) and 6 (B) respectively. The reliability of a system of  $n$  series units with  $m$  parallel elements, the reliability of a single element being  $R$ , is


$$R_s = [ 1 - ( 1 - R )^m ]^n \quad \text{----- (15)}$$

The reliability of a system with  $m$  parallel paths of  $n$  elements each, the reliability of a single element being  $R$ , is

$$R_s = [ 1 - ( 1 - R^n )^m ] \quad \text{----- (16)}$$

Series-parallel configurations result in higher reliability than equivalent parallel-series configurations. Smith (4) has described that as the reliability of unit increases, the difference between series-parallel & parallel-series reliabilities decrease.





2. FORMULATION OF THE  
PROBLEM

2.1. PERFORMANCE CRITERION

The system is considered to be performing adequately well or satisfactorily so long as it is delivering power, may be at the rated or derated levels. In the present case, the system consists of unit I of Guru Nanak Dev Thermal Plant at Bhatinda.

2.2. PROBLEM

Unit I of the existing 4x110 M.W. units of Guru Nanak Dev Thermal Plant, Bhatinda (Punjab) owned & operated by Punjab State Electricity Board has been taken up for the present study. The problem deals with the analytical determination of reliability of unit I of the G.N.D. Thermal Plant. The working of the unit for the period from 1.1.77, 00 Hrs to 17.10.77, 16.40 Hrs. was considered for the said purpose. The data so obtained was used in the evaluation of system reliability. The unit consists of the following sub-systems/elements.

1. Water Treatment Plant.
2. Fuel Oil System.
3. Coal Plant.
4. Boiler Auxillaries.

5. Main Boiler.
6. Turbine Auxillaries.
7. Turbine.
8. Generator/Exciter.
9. Electrical Equipment.
10. Instruments/Controls.
11. System Outer Grid.
12. Shortages.
13. Ash Handling System.

### 2.3 DATA

The break down time of the unit I is included in Table I.

This data has been critically examined and the various types of failures leading to system break down have been studied. Accordingly various subsystems/components and their breakdown times have been sorted out. Tables II to IX include data pertaining to breakdown times of Fuel Oil System, Boiler Auxillaries, Main Boiler, Turbine Auxillaries, Turbine, Generator/Exciter, Electrical Equipment and Instruments/controls respectively.

### 2.4 SOLUTION TECHNIQUE.

#### 2.4.1 DETERMINATION OF COMPONENT AND SYSTEM RELIABILITY

Following steps indicate the outline of methodology adopted for the determination of component & system reliability.

- i) Collection of Data i.e. breakdown time of the Unit I.

- ii) Sorting out various sub-systems and their break down times based on the failure mechanism of the system.
- iii) Study of Sub-system-System relationship on functional basis.
- iv) Development of Functional Block Diagram.
- v) Development of Reliability Block Diagram.

From the Data given in Tables II to IX, following information is obtained:

- (a) Total operating time of the system.
- (b) Failure time of the sub-systems/Constituent Components at random.

On account of the limitations of the "Probability Density Function Method" and "Weibull Function Method", the technique stated in section (1.2.2) is made use of for the determination of the constituent components/Subsystems reliability Accordingly,

Reliability of the  
Constituent Component =

$$= \frac{1 - \text{Cumulated failure time of each Component}}{\text{Total operating time of the system.}}$$

Further, various components and their grouping has been studied and analysed on functional basis (i.e. Required for Power Generation). The system-component relationship on functional basis, whether the system is operating at full rated load or part load is shown in Fig (7). In the "Reliability Block Diagram", Fig (10), following components/Sub-systems have been omitted for the reasons mentioned against

each.

- (i) Outergrid (For transmission of Power): Sub-system falling outside the purview of power generation.
- (ii) Shortages (Coal) : Sub-system falling outside the purview of power generation.
- (iii) Ash Handling System: Sub-system having no failure time during the period under study.
- (iv) Water Treatment Plant: Sub-system having no failure time during the period under study.

Further, the reliability block-diagrams on functional basis for individual sub-systems are shown in Fig.(8 ). Also the reliability block-diagram for Boiler Auxiliaries, on function basis, is shown in Fig.(9).

From the reliability block-diagram of the system shown in Fig.(10), it is clear that the system has a series configuration.



TABLE I

BREAKDOWN TIME OF THE UNIT

| S.No. | Date,<br>Month<br>&<br>Year | Period |      | Duration |      | Reasons  |
|-------|-----------------------------|--------|------|----------|------|--|
|       |                             | From   | To   | Hrs.     | Min. |  |
| 1.    | 1.1.77                      | 1415   | 2400 | 09       | 45   | Unit tripped<br>due to low fuel<br>oil pressure.         |
|       | 2.1.77                      | 0000   | 0200 | 02       | 00   |  |
| 2.    | 5.1.77                      | 1625   | 1912 | 02       | 47   | Unit tripped due<br>to system fault.                     |
| 3.    | 6.1.77                      | 1600   | 1630 | 00       | 30   | Unit tripped on<br>axial shift.                          |
| 4.    | 6.1.77                      | 1710   | 2400 | 06       | 50   | Unit stopped to<br>check up axial<br>shift.              |
|       | 7.1.77                      | 0000   | 2400 | 24       | 00   |  |
|       | 8.1.77                      | 0000   | 2400 | 24       | 00   |  |
|       | 9.1.77                      | 0000   | 2028 | 20       | 28   |  |
| 5.    | 14.1.77                     | 0925   | 1110 | 01       | 45   | Unit tripped due<br>to distribution<br>oil pressure low. |
| 6.    | 19.1.77                     | 1145   | 1306 | 01       | 21   | Unit tripped due<br>to mal-operation<br>of TTX relay.    |
| 7.    | 22.1.77                     | 1757   | 1808 | 00       | 11   | Unit tripped due<br>to high axial<br>shift.              |
| 8.    | 25.1.77                     | 1115   | 1207 | 00       | 52   | Unit tripped on<br>rotor earth fault.                    |

|     |         |      |      |    |    |  |
|-----|---------|------|------|----|----|--|
| 9.  | 30.1.77 | 1233 | 1439 | 02 | 06 | Unit tripped on system fault.                                |
| 10. | 4.2.77  | 1258 | 2400 | 11 | 02 | Unit tripped on rotor earth fault.                           |
|     | 5.2.77  | 0000 | 2337 | 23 | 37 |  |
| 11. | 6.2.77  | 0012 | 0044 | 00 | 32 | Unit tripped on reverse power.                               |
| 12. | 6.2.77  | 1120 | 2400 | 12 | 40 | Unit tripped to attend heavy leakage in H.P. injection line. |
|     | 7.2.77  | 0000 | 0902 | 09 | 02 |  |
| 13. | 16.2.77 | 1817 | 1838 | 00 | 21 | Unit tripped on axial shift high & due to load throw off.    |
| 14. | 23.2.77 | 1220 | 1230 | 00 | 10 | Unit tripped on axial shift high.                            |
| 15. | 25.2.77 | 0905 | 0955 | 00 | 50 | Unit tripped on axial shift high.                            |
| 16. | 26.2.77 | 2005 | 2400 | 03 | 55 | Unit stopped to attend leakage on boiler & turbine side.     |
|     | 27.2.77 | 0000 | 2400 | 24 | 00 |  |
|     | 28.2.77 | 0000 | 2400 | 24 | 00 |  |
|     | 1.3.77  | 0000 | 2400 | 24 | 00 |  |
|     | 2.3.77  | 0000 | 0104 | 01 | 04 |  |
| 17. | 2.3.77  | 1055 | 2400 | 13 | 05 | Unit tripped without any initiating cause.                   |
|     | 3.3.77  | 0000 | 1614 | 16 | 14 |  |
| 18. | 6.3.77  | 1004 | 1023 | 00 | 19 | Unit tripped manually to clean slip rings of exciter.        |

|     |         |      |      |    |    |  |
|-----|---------|------|------|----|----|--|
| 19. | 10.3.77 | 1942 | 2400 | 04 | 18 | Unit tripped due to burning of furnace draft cables.                               |
|     | 11.3.77 | 0000 | 0723 | 07 | 23 |  |
| 20. | 15.3.77 | 2107 | 2145 | 00 | 38 | Unit tripped as the generator breaker opened.                                      |
| 21. | 21.3.77 | 1243 | 1328 | 00 | 45 | Unit tripped manually to clean exciter brushes.                                    |
| 22. | 21.3.77 | 1337 | 1730 | 03 | 53 | Unit tripped on rotor earth fault.   |
| 23. | 22.3.77 | 0840 | 2400 | 15 | 20 | Unit tripped manually due to critical position of pulverised coal & P.C. feeders.  |
|     | 23.3.77 | 0000 | 0145 | 01 | 45 |  |
| 24. | 23.3.77 | 1100 | 2153 | 10 | 53 | Unit tripped manually due to non-availability of coal mills & P.C. feeders.        |
| 25. | 26.3.77 | 0012 | 0310 | 02 | 58 | Unit tripped on negative sequence.   |
| 26. | 29.3.77 | 1731 | 1957 | 02 | 26 | Unit tripped manually due to trouble with both I.D.Fans.                           |
| 27. | 30.3.77 | 1555 | 1637 | 00 | 42 | Unit tripped manually due to excessive knocking found in the only running F.D.Fan. |

|     |               |      |      |     |    |  |
|-----|---------------|------|------|-----|----|--|
| 28. | 31.3.77       | 0442 | 2400 | 19  | 18 | Unit tripped because of high bearing temp. of I.D. Fan.Planned shut down.                              |
|     | TO<br>24.4.77 |      | 0147 | 553 | 47 |  |
| 29. | 25.4.77       | 0534 | 0605 | 00  | 31 | Unit tripped due to thrust bearing failure hydro-mechanical trip.                                      |
| 30. | 26.4.77       | 2335 | 2400 | 00  | 25 | Unit tripped to attend leakage of inching by pass valve & B.D. valve & to rectify P.C. Burner nozzles. |
|     | 27.4.77       | 0000 | 2400 | 24  | 00 |  |
|     | 28.4.77       | 0000 | 2400 | 24  | 00 |  |
|     | 29.4.77       | 0000 | 2400 | 24  | 00 |  |
|     | 30.4.77       | 0000 | 2400 | 24  | 00 |  |
|     | 1.5.77        | 0000 | 2400 |     |    |  |
|     | TO<br>9.5.77  | 0000 | 2155 | 213 | 55 |  |
| 31. | 9.5.77        | 2205 | 2400 | 01  | 55 | Unit tripped due to sudden variation in furnace draft.   |
|     | 10.5.77       | 0000 | 0350 | 03  | 50 |  |
| 32. | 10.5.77       | 0353 | 1432 | 10  | 39 | Unit tripped due to sudden variation in furnace draft.   |
| 33. | 10.5.77       | 1540 | 2400 | 08  | 20 | Unit tripped manually due to H.P. eccentricity being high.   |
|     | 11.5.77       | 0000 | 1002 | 10  | 02 |  |
| 34. | 11.5.77       | 1022 | 1045 | 00  | 23 | Unit tripped manually as both inter-ceptor valves closed.  |
| 35. | 15.5.77       | 0120 | 0527 | 04  | 07 | Unit tripped on rotor earth fault.   |

|     |         |      |      |    |    |  |
|-----|---------|------|------|----|----|--|
| 36. | 15.5.77 | 0540 | 0650 | 01 | 10 | Unit tripped on furnace draft high. I.D.Fan inter-connecting damper closed of its own. |
| 37. | 16.5.77 | 0635 | 1055 | 04 | 20 | Unit tripped due to low frequency.   |
| 38. | 17.5.77 | 1453 | 2053 | 06 | 00 | Unit tripped due to low frequency.   |
| 39. | 20.5.77 | 1012 | 1220 | 02 | 08 | Unit desynchronised.   |
| 40. | 22.5.77 | 0210 | 0225 | 00 | 15 | Unit tripped as M.F.T. tripped due to low furnace oil pressure.                        |
| 41. | 23.5.77 | 1832 | 2400 | 05 | 28 | Unit tripped due to  |
|     | 24.5.77 | 0000 | 2400 | 24 | 00 | operation of VAT Buck-   |
|     | 25.5.77 | 0000 | 2400 | 24 | 00 | holz's relay.  |
|     | 26.5.77 | 0000 | 1426 | 14 | 26 |  |
| 42. | 31.5.77 | 1742 | 2400 | 06 | 18 | Unit tripped due to  |
|     | To      |      |      |    |    | suspected leakage in   |
|     | 3.6.77  |      | 1620 | 64 | 20 | economiser.  |
| 43. | 3.6.77  | 1630 | 1945 | 03 | 15 | Unit tripped on thrust bearing hydromechanical trip.                                   |
| 44. | 5.6.77  | 1355 | 1852 | 04 | 57 | Unit tripped due to low system frequency.  |
| 45. | 9.6.77  | 0738 | 0845 | 01 | 07 | Unit tripped due to M.F.T. trip.   |

|     |         |      |             |           |    |   |
|-----|---------|------|-------------|-----------|----|---|
| 46. | 13.6.77 | 0140 | 1540        | 14        | 00 | Unit tripped due to M.F.T. trip.  |
| 47. | 19.6.77 | 1421 | <b>2400</b> | 09        | 39 | Unit tripped manually to attend drum manhole leakage.   |
|     | 20.6.77 | 0000 | 2400        | <b>24</b> | 00 |   |
|     | 21.6.77 | 0000 | 1121        | 11        | 21 |   |
| 48. | 23.6.77 | 2115 | 2158        | 00        | 43 | Unit tripped due to system fault.   |
| 49. | 24.6.77 | 1453 | 1730        | 02        | 37 | Unit tripped due to system fault.   |
| 50. | 25.6.77 | 0445 | 0834        | 03        | 49 | Unit tripped due to low frequency.  |
| 51. | 25.6.77 | 2225 | 2400        | 01        | 35 | Unit tripped due to push button.  |
|     | 26.6.77 | 0000 | 2400        | 24        | 00 |   |
|     | 27.6.77 | 0000 | 0534        | 05        | 34 |   |
| 52. | 27.6.77 | 1512 | 1540        | 00        | 28 | Unit tripped on exhaust pressure high.  |
| 53. | 8.7.77  | 1650 | 2400        | 07        | 10 | Unit tripped due to the tripping of only available I.D. Fan.                                  |
|     | 9.7.77  | 0000 | 2400        | 24        | 00 |   |
|     | 10.7.77 | 0000 | 0525        | 05        | 25 |   |
| 54. | 12.7.77 | 1600 | 2028        | 04        | 28 | Unit tripped manually to attend damaged diaphragms of I.D. Fan.                               |
| 55. | 13.7.77 | 2200 | 2400        | 02        | 00 | Unit tripped manually to attend the leakage at the flange of safety valve of B.D. valve line. |
|     | 14.7.77 | 0000 | 0132        | 01        | 32 |   |

|     |         |      |      |    |    |  |
|-----|---------|------|------|----|----|--|
| 56. | 27.7.77 | 1247 | 2158 | 09 | 11 | Unit tripped due to the tripping of M.F.T. on I.D. Fan failure.              |
| 57. | 28.7.77 | 0655 | 2400 | 17 | 05 | Unit tripped due to the tripping of M.F.T. on I.D.Fan failure.               |
|     | 29.7.77 | 0000 | 2400 | 24 | 00 |  |
|     | 30.7.77 | 0000 | 2400 | 24 | 00 |  |
|     | 31.7.77 | 0000 | 2400 | 24 | 00 |  |
|     | 1.8.77  | 0000 | 1334 | 13 | 34 |  |
| 58. | 9.8.77  | 0327 | 1305 | 09 | 38 | Unit tripped due to trouble in coal handling plant.                          |
| 59. | 9.8.77  | 2330 | 2338 | 00 | 08 | Unit tripped due to heavy load fluctuation on the system.                    |
| 60. | 16.8.77 | 0435 | 2400 | 19 | 25 | Unit tripped due to trouble in only available I.D.Fan.                       |
|     | 17.8.77 | 0000 | 2400 | 24 | 00 |  |
|     | 18.8.77 | 0000 | 2022 | 20 | 22 |  |
| 61. | 28.8.77 | 1355 | 1538 | 01 | 43 | Unit tripped on furnace draft high.  |
| 62. | 31.8.77 | 1140 | 1210 | 00 | 30 | Unit tripped due to tripping of only running F.D.Fan.                        |
| 63. | 3.9.77  | 2343 | 2400 | 00 | 17 | Unit tripped due to tripping of only available I.D.Fan on thermal over load. |
|     | 4.9.77  | 0000 | 0043 | 00 | 43 |  |
| 64. | 4.9.77  | 2157 | 2400 | 02 | 03 | Unit tripped due to tripping of only available I.D.Fan on thermal over load. |
|     | 5.9.77  | 0000 | 0005 | 00 | 05 |  |

|     |               |      |      |     |    |  |
|-----|---------------|------|------|-----|----|--|
| 65. | 14.9.77       | 0825 | 2400 | 15  | 35 | Unit tripped manually<br>for attending to various<br>faults in boiler & turbine.   |
|     | To<br>19.9.77 | 0000 | 1824 | 114 | 24 |  |
| 66. | 21.9.77       | 0730 | 2400 | 16  | 30 | Unit tripped manually as<br>instruments supply failed<br>due to tripping of station<br>transformer II on its<br>fire protection air pr. low. |
|     | 22.9.77       | 0000 | 0431 | 04  | 31 |  |
| 67. | 22.9.77       | 0442 | 0723 | 02  | 41 | Unit tripped as M.F.T.<br>tripped on abnormal furna-<br>ce draft.  |
| 68. | 22.9.77       | 0812 | 1030 | 02  | 18 | Unit tripped manually<br>due to tripping of B.F.P.<br>on balancing leak off<br>pressure high.  |
| 69. | 27.9.77       | 1520 | 2017 | 04  | 57 | Unit tripped due to the<br>tripping of both C.W.<br>pumps on condenser pr.<br>high.  |
| 70. | 27.9.77       | 2330 | 2400 | 00  | 30 | Unit tripped due to the<br>tripping of both C.W.<br>pumps on condenser pr.<br>high.  |
|     | 28.9.77       | 0000 | 0423 | 04  | 23 |  |
| 71. | 30.9.77       | 1105 | 1138 | 00  | 30 | Unit tripped due to<br>failure of M.C.C. supply<br>while changeover.   |

|     |          |      |      |     |    |   |
|-----|----------|------|------|-----|----|---|
| 72. | 6.10.77  | 0645 | 0812 | 01  | 27 | Unit tripped due to mal functioning of bus-coupler.                             |
| 73. | 7.10.77  | 0155 | 2400 | 22  | 05 | Unit tripped due to suspected leakage in super heater.                          |
|     | 8.10.77  | 0000 | 2400 | 24  | 00 |   |
|     | 9.10.77  | 0000 | 2400 | 24  | 00 |   |
|     | 10.10.77 | 0000 | 0210 | 02  | 10 |   |
| 74. | 12.10.77 | 1636 | 1812 | 01  | 36 | Unit tripped due to generator field earth fault.                                |
| 75. | 13.10.77 | 0927 | 2400 | 14  | 33 | Unit tripped due to system disturbance & rotor earth fault.                     |
|     | 14.10.77 | 0000 | 1015 | 10  | 15 |   |
| 76. | 14.10.77 | 1103 | 1518 | 04  | 15 | Unit tripped due to malfunctioning of axial shift relay.                        |
| 77. | 17.10.77 | 1023 | 1332 | 03  | 09 | Unit tripped manually through M.F.T. as both C.W. pumps had tripped.            |
| 78. | 11.11.77 | 1628 | 2400 | 07  | 32 | Unit tripped manually to attend various faults on boiler & turbine side.        |
|     | TO       |      |      |     |    |   |
|     | 16.11.77 | 0000 | 2137 | 125 | 09 |   |
| 79. | 17.11.77 | 0105 | 2400 | 22  | 55 | Unit tripped manually to attend leakage on auxiliary injection line right side. |
|     | 18.11.77 | 0000 | 0908 | 09  | 08 |   |

|     |          |      |      |    |    |                             |
|-----|----------|------|------|----|----|-----------------------------|
| 80. | 18.11.77 | 2353 | 2400 | 00 | 07 | Unit tripped manually       |
|     | 19.11.77 | 0000 | 2400 | 24 | 00 | to attend the H P radial    |
|     | 20.11.77 | 0000 | 0403 | 04 | 03 | bearing front of turbine.   |
| 81. | 26.11.77 | 1130 | 1229 | 00 | 59 | Unit tripped on exhaust     |
|     |          |      |      |    |    | pressure high.              |
| 82. | 26.11.77 | 1254 | 1433 | 01 | 39 | Unit tripped on exhaust     |
|     |          |      |      |    |    | pressure high.              |
| 83. | 7.12.77  | 2108 | 2205 | 00 | 57 | Unit desynchronised for     |
|     |          |      |      |    |    | cleaning exciter brushes.   |
| 84. | 8.12.77  | 1700 | 2000 | 03 | 00 | Unit tripped due to         |
|     |          |      |      |    |    | exhaust pressure high.      |
| 85. | 8.12.77  | 2312 | 2400 | 00 | 48 | Unit tripped due to         |
|     | 9.12.77  | 0000 | 1638 | 16 | 38 | attend speeder gear.        |
| 86. | 15.12.77 | 2055 | 2242 | 01 | 47 | Unit tripped manually       |
|     |          |      |      |    |    | to attend sparking on       |
|     |          |      |      |    |    | slip rings of generators.   |
| 87. | 15.12.77 | 2300 | 2400 | 01 | 00 | Unit tripped due to the     |
|     | 16.12.77 | 0000 | 0305 | 03 | 05 | tripping of all auxiliaries |
|     |          |      |      |    |    | on under voltage.           |
| 88. | 19.12.77 | 0837 | 1037 | 02 | 00 | Unit tripped on rotor       |
|     |          |      |      |    |    | earth fault.                |
| 89. | 21.12.77 | 0935 | 2110 | 11 | 35 | Unit tripped manually       |
|     |          |      |      |    |    | to attend leakage in the    |
|     |          |      |      |    |    | deaeration line of dis-     |
|     |          |      |      |    |    | charge line of M.O.P.       |
| 90. | 29.12.77 | 1613 | 2400 | 07 | 47 | Unit tripped manually to    |
|     | TO       |      |      |    |    | attend leakage in eco-      |
|     | 2.1.78   | 0000 | 1750 | 89 | 50 | nomiser section.            |

|      |               |      |      |     |    |   |
|------|---------------|------|------|-----|----|---|
| 91.  | 12.1.78       | 1040 | 2400 | 13  | 20 | Unit tripped manually<br>to attend leakage at<br>B.D. valve.                                    |
|      | 13.1.78       | 0000 | 2400 | 24  | 00 |   |
|      | 14.1.78       | 0000 | 2400 | 24  | 00 |   |
|      | 15.1.78       | 0000 | 0238 | 023 | 38 |   |
| 92.  | 15.1.78       | 0310 | 0332 | 00  | 22 | Unit tripped on hydro-<br>mechanical trip.  |
| 93.  | 2.2.78        | 1501 | 2400 | 08  | 59 | Unit tripped manually<br>due to suspected leakage<br>in economiser zone &<br>wall super heater. |
|      | TO<br>24.2.78 | 0000 | 0858 | 512 | 58 |   |
| 94.  | 24.2.78       | 0917 | 1010 | 00  | 53 | Unit tripped on exhaust<br>pressure high.   |
| 95.  | 24.2.78       | 1025 | 2400 | 13  | 35 | Unit tripped manually<br>due to high differential<br>expansion.                                 |
|      | 25.2.78       | 0000 | 2400 | 24  | 00 |   |
|      | 26.2.78       | 0000 | 1634 | 16  | 34 |   |
| 96.  | 26.2.78       | 1734 | 2400 | 06  | 26 | Unit tripped by tripping<br>turbine.  |
|      | 27.2.77       | 0000 | 0034 | 00  | 34 |   |
| 97.  | 1.3.77        | 1302 | 1325 | 00  | 23 | Unit tripped due to low<br>vaccum.  |
| 98.  | 4.3.78        | 2300 | 2400 | 01  | 00 | Unit tripped manually<br>to clean the B.F.P.<br>suction strainer.                               |
|      | 5.3.78        | 0000 | 0946 | 09  | 46 |   |
| 99.  | 6.3.78        | 1140 | 1205 | 00  | 25 | Unit tripped on rotor<br>earth fault.   |
| 100. | 6.3.78        | 1905 | 2400 | 04  | 55 | Unit tripped due to total<br>supply failure.  |
|      | 7.3.78        | 0000 | 0303 | 03  | 03 |   |

|      |         |      |      |     |    |   |
|------|---------|------|------|-----|----|---|
| 101. | 9.3.78  | 1304 | 1755 | 04  | 51 | Unit tripped on rotor earth fault.      |
| 102. | 9.3.78  | 1820 | 2400 | 05  | 40 | Unit tripped due to                     |
|      | 10.3.78 | 0000 | 1632 | 16  | 32 | bursting of injection line of B.P.-2.   |
| 103. | 11.3.78 | 0248 | 2400 | 21  | 12 | Unit tripped due to                     |
|      | To      |      |      |     |    | leakage in boiler because               |
|      | 24.3.78 | 0000 | 1436 | 302 | 36 | of chocking of reheater tube.           |
| 104. | 24.3.78 | 1737 | 2400 | 06  | 23 | Unit tripped due to                     |
|      | 25.3.78 | 0000 | 0550 | 05  | 50 | tripping of M.F.T.                      |
| 105. | 25.3.78 | 0605 | 1728 | 11  | 23 | Unit tripped due to                     |
|      |         |      |      |     |    | L.P. rotor differential expansion high. |
| 106. | 30.3.78 | 1757 | 2400 | 06  | 03 | Unit tripped manually                   |
|      | To      |      |      |     |    | due to suspected leakage                |
|      | 5.4.78  | 0000 | 2150 | 141 | 50 | in reheater.                            |
| 107. | 6.4.78  | 1100 | 1243 | 01  | 41 | Unit tripped due to                     |
|      |         |      |      |     |    | rotor earth fault.                      |
| 108. | 8.4.78  | 1515 | 1632 | 01  | 17 | Unit tripped manually                   |
|      |         |      |      |     |    | due to tripping of B.F.P.               |
| 109. | 10.4.78 | 0427 | 0610 | 01  | 43 | Unit tripped due to the                 |
|      |         |      |      |     |    | tripping of auto trans-                 |
|      |         |      |      |     |    | former on over load.                    |
| 110. | 10.4.78 | 0900 | 1255 | 03  | 55 | Unit tripped on rotor                   |
|      |         |      |      |     |    | earth fault.                            |

|      |         |      |      |        |    |  |
|------|---------|------|------|--------|----|--|
| 111. | 11.4.78 | 1622 | 1732 | 01     | 10 | Unit tripped on rotor earth fault.   |
| 112. | 11.4.78 | 2040 | 2400 | 03     | 20 | Unit tripped to attend leakage on the impulse line indicating pressure in B.P.E.1. |
|      | 12.4.78 | 0000 | 1542 | 15     | 42 |  |
| 113. | 12.4.78 | 1616 | 1715 | 00     | 59 | Unit tripped on hydro-machanical trip.   |
| 114. | 19.4.78 | 0935 | 1045 | 01     | 10 | Unit tripped due to system disturbance.  |
| 115. | 25.4.78 | 2000 | 2400 | 04     | 00 | Unit tripped due to excessive leakage in the generator seal oil system.            |
|      | 26.4.78 | 0000 | 2400 | 24     | 00 |  |
|      | 27.4.78 | 0000 | 1521 | 15     | 21 |  |
| 116. | 28.4.78 | 2303 | 2400 | 00     | 57 | Unit tripped manually to attend fault on T <sub>G</sub> side.                      |
|      | 29.4.78 | 0000 | 0327 | 03     | 27 |  |
| 117. | 29.4.78 | 0543 | 0905 | 03     | 22 | Unit tripped on rotor earth fault.   |
| 118. | 2.5.78  | 1620 | 1628 | 00     | 08 | Unit des <sup>n</sup> ynchronised due to system fault.                             |
| 119. | 3.5.78  | 1602 | 2305 | 07     | 03 | Unit tripped due to system disturbance.  |
| 120. | 6.5.78  | 2345 | 2400 | 00     | 15 | Unit tripped on fuel oil pressure low.   |
|      | 7.5.78  | 0000 | 0220 | 02     | 20 |  |
| 121. | 8.5.78  | 0850 | 1026 | 013636 |    | Unit tripped on B.F.P.1A tripped on over current in Y - phase.                     |

|      |         |      |      |     |    |   |
|------|---------|------|------|-----|----|---|
| 122  | 10.5.78 | 0000 | 0036 | 00  | 36 | Unit tripped on fuel oil pressure low.  |
| 123. | 16.5.78 | 2310 | 2400 | 00  | 50 | Unit tripped due to abnormal furnace draft.   |
|      | 17.5.78 | 0000 | 0000 |     |    |   |
| 124. | 23.5.78 | 2005 | 2050 | 00  | 45 | Unit tripped manually as vaccum was falling due to low reheat pr.   |
| 125. | 23.5.78 | 2235 | 2400 | 01  | 25 | Unit tripped manually as vaccum was falling due to low reheat pr.   |
| 126. | 27.5.78 | 0803 | 0829 | 00  | 26 | Unit tripped on thrust bearing failure hydro-lic trip.  |
| 127. | 27.5.78 | 1440 | 2400 | 09  | 20 | Unit tripped as both the R-C chain feeders became chocked & drum pressure was reduced & subsequently unit tripped on low vaccum pressure. |
|      | 28.5.78 | 0000 | 0345 | 03  | 45 |   |
| 128. | 31.5.78 | 1745 | 2400 | 06  | 15 | Unit tripped on fuel oil pressure low.  |
| 129. | 1.6.78  | 0000 | 0440 | 04  | 40 |   |
| 129. | 3.6.78  | 0512 | 2400 | 18  | 48 | Unit tripped manually due to suspected leakage in boiler pent house.  |
|      | to      |      |      |     |    |   |
|      | 23.6.78 | 0000 | 2032 | 476 | 32 |   |

|      |         |      |      |    |    |   |
|------|---------|------|------|----|----|---|
| 130. | 23.6.78 | 2139 | 2400 | 02 | 21 | Unit tripped manually due to M.P. rotor differential expansion high.                      |
|      | 24.6.78 | 0000 | 1308 | 13 | 08 |   |
| 131  | 25.6.78 | 0925 | 1043 | 01 | 18 | Unit tripped on low fuel oil pressure.  |
| 132  | 25.6.78 | 1080 | 1550 | 05 | 00 | Unit tripped due to tripping of only available I.D.Fan due to abnormal sound in impeller. |
| 133  | 25.6.78 | 1957 | 2005 | 00 | 08 | Unit tripped due to system disturbance at over speed.                                     |
| 134  | 26.6.78 | 0126 | 0304 | 01 | 38 | Unit/turbine tripped manually due to excessive knocking noise in the reduction gear box.  |
| 135  | 26.6.78 | 1440 | 2400 | 09 | 20 | Unit tripped manually due to leakage in economiser.                                       |
|      | 27.6.78 | 0000 | 2400 | 24 | 00 |   |
|      | 28.6.78 | 0000 | 2400 | 24 | 00 |   |
|      | 29.6.78 | 0000 | 2400 | 24 | 00 |   |
|      | 30.6.78 | 0000 | 2400 | 24 | 00 |   |
|      | 1.7.78  | 0000 | 2400 | 24 | 00 |   |
|      | 2.7.78  | 0000 | 2400 | 24 | 00 |   |
|      | 3.7.78  | 0000 | 2100 | 21 | 00 |   |
| 136  | 4.7.78  | 0015 | 2400 | 23 | 45 | Unit tripped manually due to non-availability of coal mills.                              |
|      | 5.7.78  | 0000 | 0110 | 01 | 10 |   |

|      |         |      |      |    |    |  |
|------|---------|------|------|----|----|--|
| 137. | 9.7.78  | 1202 | 2400 | 11 | 58 | Unit tripped manually due to stopping of only available I.D.Fan due to abnormal sound. |
|      | 10.7.78 | 0000 | 2400 | 24 | 00 |  |
|      | 11.7.78 | 0000 | 0313 | 03 | 13 |  |
| 138. | 16.7.78 | 0627 | 2400 | 17 | 33 | Unit tripped due to leakage in the economiser.   |
|      | 17.7.78 | 0000 | 2400 | 24 | 00 |  |
|      | 18.7.78 | 0000 | 2400 | 24 | 00 |  |
|      | 19.7.78 | 0000 | 1205 | 12 | 05 |  |
| 139. | 22.7.78 | 0340 | 0530 | 01 | 50 | Unit tripped due to tripping of F.O.pump & pressure went low.                          |
| 140. | 27.7.78 | 0738 | 2400 | 16 | 22 | Unit tripped by tripping TO TTX relay.   |
|      | 31.7.78 | 0000 | 2145 | 93 | 45 |  |
| 141. | 31.7.78 | 2155 | 2400 | 02 | 05 | Unit tripped due to exhaust pressure high.   |
|      | 1.8.78  | 0000 | 1223 | 12 | 23 |  |
| 142. | 3.8.78  | 1423 | 1540 | 01 | 17 | Unit tripped on fuel oil pressure low.   |
| 143  | 5.8.78  | 0359 | 1020 | 06 | 21 | Unit tripped due to loss of excitation.  |
| 144. | 5.8.78  | 1605 | 1659 | 00 | 54 | Unit tripped due to loss of excitation.  |
| 145. | 11.8.78 | 0040 | 0440 | 04 | 02 | Unit tripped due to trouble in generator seal oil system.                              |
| 146. | 18.8.78 | 0800 | 0907 | 01 | 07 | Unit tripped due to furnace draft abnormal.  |

|      |         |      |      |      |    |   |
|------|---------|------|------|------|----|---|
| 147. | 18.8.78 | 0909 | 0925 | 00   | 16 | Unit tripped on distribution oil pressure low.              |
| 148. | 20.8.78 | 1812 | 1953 | 01   | 41 | Unit tripped due to exhaust pressure high.                  |
| 149. | 20.8.78 | 2005 | 2045 | 00   | 40 | Unit tripped due to distribution oil pressure low.          |
| 150. | 29.8.78 | 0115 | 1335 | 12   | 20 | Unit tripped due to leakage in the discharge line of B.F.P. |
| 151. | 7.9.78  | 1535 | 1829 | 02   | 54 | Unit tripped on no coal.                                    |
| 152. | 12.9.78 | 0901 | 2400 | 14   | 59 | Unit tripped due to flash on B.F.P. motor.                  |
|      | 13.9.78 | 0000 | 2400 | 24   | 00 |   |
|      | 14.9.78 | 0000 | 0440 | 04   | 40 |   |
| 153. | 14.9.78 | 0500 | 0523 | 00   | 23 | Unit tripped on hydromechanical trip.                       |
| 154. | 14.9.78 | 0546 | 0602 | 00   | 16 | Unit tripped on distribution oil pressure low.              |
| 155. | 15.9.78 | 1905 | 2245 | 03   | 40 | Unit tripped due to leakage of oil from generator.          |
| 156. | 18.9.78 | 1317 | 1403 | 00   | 46 | Unit tripped due to fuel oil pressure low.                  |
| 157. | 18.9.78 | 1413 | 1430 | 00   | 17 | Unit tripped on distribution oil pressure low.              |
| 158. | 19.9.78 | 1700 | 2400 | 07   | 00 | Unit tripped due to fire on turbine.                        |
|      | TO      |      |      |      |    |   |
|      | 4.10.78 | 0000 | 0958 | 345. | 58 |   |

|      |          |      |      |     |    |  |
|------|----------|------|------|-----|----|--|
| 159. | 4.10.78  | 1005 | 1125 | 01  | 20 | Unit tripped on hydro-mechanical trip. |
| 160. | 11.10.78 | 1500 | 2145 | 06  | 37 | Unit tripped due to system fault.      |
| 161. | 11.10.78 | 2307 | 2400 | 00  | 51 | Unit tripped due to mal-               |
|      | TO       |      |      |     |    |  |
|      | 18.10.78 | 0000 | 1640 | 161 | 33 | functioning of A.V.R.                  |

The unit was released for capital maintenance w.e.f. 18.10.78, 1640 Hrs. The unit was synchronised with the system on 27.1.79 at 1110 Hrs. after capital maintenance.

---

TABLE II

BREAK-DOWN TIME OF THE FUEL OIL SYSTEM

| Sr. No. | Date,<br>Month<br>&<br>Year | Period |      | Duration |      | Reasons   |
|---------|-----------------------------|--------|------|----------|------|---|
|         |                             | From   | To   | Hrs.     | Min. |   |
| 1.      | 1.1.77                      | 1415   | 2400 | 09       | 45   | Unit tripped due to low<br>fuel oil pressure.                         |
|         | 2.1.77                      | 0000   | 0200 | 02       | 00   |   |
| 2.      | 22.5.77                     | 0210   | 0225 | 00       | 15   | Unit tripped as M.F.T.<br>tripped due to low furnace<br>oil pressure. |
| 3.      | 6.5.78                      | 2345   | 2400 | 00       | 15   | Unit tripped on fuel oil<br>pressure low.                             |
|         | 7.5.78                      | 0000   | 0220 | 02       | 20   |   |
| 4.      | 10.5.78                     | 0000   | 0036 | 00       | 36   | Unit tripped on fuel oil<br>pressure low.                             |
| 5.      | 31.5.78                     | 1745   | 2400 | 06       | 15   | Unit tripped on fuel oil<br>pressure low.                             |
|         | 1.6.78                      | 0000   | 0440 | 04       | 40   |   |
| 6.      | 25.6.78                     | 0925   | 1043 | 0118     | 18   | Unit tripped on fuel oil<br>pressure low.                             |
| 7.      | 22.7.78                     | 0940   | 1130 | 01       | 50   | F.O. pumps tripped &<br>pressure went low.                            |
| 8.9     | 3.8.78                      | 1423   | 1540 | 01       | 17   | Unit tripped on fuel oil<br>pressure low.                             |
| 9.      | 18.9.78                     | 1317   | 1403 | 00       | 46   | Unit tripped on fuel oil<br>pressure low.                             |



TABLE III

BREAK DOWN TIME OF THE MAIN BOILER

| S. No. | Date, Month & Year | Period |      | Duration |      | Reasons  |
|--------|--------------------|--------|------|----------|------|--|
|        |                    | From   | To   | Hrs.     | Min. |  |
| 1.     | 26.2.77            | 2005   | 2400 | 03       | 55   | Unit stopped to attend leakage on boiler & turbine side.                                       |
|        | 27.2.77            | 0000   | 2400 | 24       | 00   |  |
|        | 28.2.77            | 0000   | 2400 | 24       | 00   |  |
| 2.     | 26.4.77            | 2335   | 2400 | 00       | 25   | Unit tripped to attend leakage of by pass valve & B.D. Valve & to rectify P.C. burner nozzles. |
|        | 9.5.77             | 0000   | 2155 | 213      | 55   |  |
| 3.     | 9.5.77             | 2205   | 2400 | 01       | 55   | Unit tripped due to sudden variation in the furnace draft.                                     |
|        | 10.5.77            | 0000   | 0350 | 03       | 50   |  |
| 4.     | 10.5.77            | 0353   | 1432 | 10       | 39   | Unit tripped due to sudden variation in the furnace draft.                                     |
| 5.     | 31.5.77            | 1742   | 2400 | 06       | 18   | Unit tripped due to suspected leakage in the economiser.                                       |
|        | 3.6.77             | 0000   | 1620 | 64       | 20   |  |
| 6.     | 13.6.77            | 0140   | 1540 | 14       | 00   | Unit tripped due to M.F.T. trip.   |
| 7.     | 19.6.77            | 1421   | 2400 | 09       | 39   | Unit tripped manually to attend drum man hole leakage.   |
|        | 20.6.77            | 0000   | 2400 | 24       | 00   |  |
|        | 21.6.77            | 0000   | 1121 | 11       | 21   |  |
| 8.     | 25.6.77            | 2225   | 2400 | 01       | 35   | Unit tripped through push button.  |
|        | 26.6.77            | 0000   | 2400 | 24       | 00   |  |
|        | 27.6.77            | 0000   | 0534 | 05       | 34   |  |

|     |          |      |      |     |    |  |
|-----|----------|------|------|-----|----|--|
| 9.  | 28.8.77  | 1355 | 1538 | 01  | 43 | Unit tripped on furnace draft high.  |
| 10. | 14.9.77  | 0825 | 2400 | 15  | 35 | Unit tripped manually  |
|     | TO       |      |      |     |    |  |
|     | 19.9.77  | 0000 | 1824 | 114 | 24 | for attending to various faults in boiler & turbine.                                     |
| 11. | 22.9.77  | 0442 | 0723 | 02  | 41 | Unit tripped as M.F.T. tripped on abnormal furnace draft.                                |
| 12. | 7.10.77  | 0155 | 2400 | 22  | 05 | Unit tripped due to suspected leakage in superheater.                                    |
|     | 8.10.77  | 0000 | 2400 | 24  | 00 |  |
|     | 9.10.77  | 0000 | 2400 | 24  | 00 |  |
|     | 10.10.77 | 0000 | 0210 | 02  | 10 |  |
| 13. | 11.11.77 | 1628 | 2400 | 07  | 32 | Unit tripped manually to attend various faults on boiler & turbine side.                 |
|     | TO       |      |      |     |    |  |
|     | 1.11.77  | 0000 | 2137 | 117 | 37 |  |
| 14. | 17.11.77 | 0105 | 2400 | 22  | 55 | Unit tripped manually to attend leakage on auxillary injection line right side.          |
|     | 18.11.77 | 0000 | 0908 | 09  | 08 |  |
| 15. | 29.12.77 | 1613 | 2400 | 07  | 47 | Unit tripped manually to attend leakage in economiser section.                           |
|     | TO       |      |      |     |    |  |
|     | 2.1.78   | 0000 | 1750 | 89  | 50 |  |
| 16. | 2.2.78   | 1501 | 2400 | 08  | 59 | Unit tripped manually due to suspected leakage in economiser zone and super heater wall. |
|     | TO       |      |      |     |    |  |
|     | 24.2.78  | 0000 | 0858 | 512 | 58 |  |

|     |         |      |      |     |    |   |
|-----|---------|------|------|-----|----|---|
| 17. | 11.3.78 | 0248 | 2400 | 21  | 12 | Unit tripped due to                                     |
|     | To      |      |      |     |    |   |
|     | 24.3.78 | 0000 | 1436 | 302 | 36 | leakage in boiler because of choking of reheater tubes. |
| 18. | 24.3.78 | 1737 | 2400 | 06  | 23 | Unit tripped due to the                                 |
|     | 25.3.78 | 0000 | 0550 | 05  | 50 | the tripping of M.F.T.                                  |
| 19. | 30.3.78 | 1757 | 2400 | 06  | 03 | Unit tripped manually                                   |
|     | To      |      |      |     |    |   |
|     | 3.4.78  | 0000 | 2150 | 141 | 50 | due to suspected leakage in reheater.                   |
| 20. | 16.5.78 | 2310 | 2400 | 00  | 50 | Unit tripped due to abnormal furnace draft.             |
| 21. | 3.6.78  | 0512 | 2400 | 18  | 48 | Unit tripped manually                                   |
|     | To      |      |      |     |    |   |
|     | 23.6.78 | 0000 | 2032 | 476 | 32 | due to suspected leakage in boiler pent house.          |
| 22. | 26.6.78 | 1440 | 2400 | 09  | 20 | Unit tripped manually due to leakage in economiser.     |
|     | To      |      |      |     |    |   |
|     | 3.7.78  | 0000 | 2100 | 165 | 00 |   |
| 23. | 16.7.78 | 0627 | 2400 | 17  | 33 | Unit tripped due to                                     |
|     | To      |      |      |     |    |   |
|     | 19.7.78 | 0000 | 1205 | 60  | 05 | leakage in the economiser                               |
| 24. | 18.8.78 | 0800 | 0907 | 01  | 07 | Unit tripped due to furnace draft abnormal.             |



TABLE IV

BREAK DOWN TIME OF THE BOILER AUXILIARIES

| S. No. | Date, Month & Year       | Period       |      | Duration |          | Reasons   |
|--------|--------------------------|--------------|------|----------|----------|---|
|        |                          | From         | To   | Hrs.     | Min.     |   |
| 1.     | 23.3.77                  | 1100         | 2153 | 10       | 53       | Unit tripped manually due to non-availability of coal mills & P.C. feeders.                           |
| 2.     | 29.3.77                  | 1731         | 1957 | 02       | 26       | Unit tripped manually due to trouble with both the I.D.Fans.  |
| 3.     | 30.3.77                  | 1555         | 1637 | 00       | 42       | Unit tripped manually due to excessive knocking sound in the only running F.D.Fans.                   |
| 4.     | 31.3.77                  | 0442         | 2400 | 19       | 18       | Unit tripped because of high bearing temp. of I.D.Fans.   |
| 5.     | 26.4.77<br>TO<br>30.4.77 | 2335<br>0000 | 2400 | 00<br>96 | 25<br>00 | Unit tripped to attend leakage of inching by pass valve & B.D.Valve & to rectify P.C. burner nozzles. |
| 6.     | 15.5.77                  | 0540         | 0650 | 01       | 10       | Unit tripped on furnace draft high. I.D.Fan inter-connecting damper closed of its own.                |

|     |          |      |      |      |    |                           |
|-----|----------|------|------|------|----|---------------------------|
| 7.  | 8.7.77   | 1650 | 2400 | 07   | 10 | Unit tripped due to       |
|     | 9.7.77   | 0000 | 2400 | 24   | 00 | the tripping of only      |
|     | 10.7.77  | 0000 | 0525 | 05   | 25 | available I.D.Fan.        |
|     | 12.7.77  | 1600 | 2028 | 04   | 28 | Unit tripped manually     |
|     |          |      |      |      |    | to attend damaged dia-    |
|     |          |      |      |      |    | phragm of I.D.Fan.        |
| 9.  | 27.7.77  | 1247 | 2158 | 09   | 11 | Unit tripped due to       |
|     |          |      |      |      |    | tripping of MFT on        |
|     |          |      |      |      |    | I.D.Fan failure.          |
| 10. | 28.7.77  | 0655 | 2400 | 17   | 05 | Unit tripped due to       |
|     | To       |      |      |      |    | the tripping of MFT       |
|     | 1.8.77   | 0000 | 1334 | 85   | 34 | on I.D.Fan failure.       |
| 11. | 31.8.77  | 1140 | 1210 | 00   | 30 | Unit tripped due to       |
|     |          |      |      |      |    | tripping of only runn-    |
|     |          |      |      |      |    | ing F.D.Fan.              |
| 12. | 11.11.77 | 1628 | 2400 | 07   | 32 | Unit tripped manually     |
|     | To       |      |      |      |    | to attend various faults  |
|     | 16.11.77 | 0000 | 2137 | 117  | 37 | on boiler & turbine side. |
| 13. | 27.5.78  | 1440 | 2400 | 09   | 20 | Unit tripped as both      |
|     | 28.5.78  | 0000 | 0345 | 03   | 45 | the R.C.chain feeders     |
|     |          |      |      |      |    | became choked & drum      |
|     |          |      |      |      |    | pr. was reduced & sub-    |
|     |          |      |      |      |    | sequently unit tripped    |
|     |          |      |      |      |    | on low vaccum pressure.   |
| 14. | 25.6.78  | 1050 | 1550 | 0500 | 00 | Unit tripped due to       |
|     |          |      |      |      |    | tripping of only avail-   |
|     |          |      |      |      |    | able I.D.Fan due to       |
|     |          |      |      |      |    | abnormal sound in impell- |
|     |          |      |      |      |    | er.                       |

|            |      |      |    |    |  |
|------------|------|------|----|----|--|
| 15. 9.7.78 | 1202 | 2400 | 11 | 58 | Unit tripped manually                            |
| 10.7.78    | 0000 | 2400 | 24 | 00 | due to stopping of                               |
| 11.7.78    | 0000 | 0313 | 03 | 13 | only available I.D.Fan<br>due to abnormal sound. |



TABLE V

BREAK DOWN TIME OF THE TURBINE

| S. No. | Date, Month & Years | Period |      | Duration |      | Reasons  |
|--------|---------------------|--------|------|----------|------|--|
|        |                     | From   | To   | Hrs.     | Min. |  |
| 1.     | 14.1.77             | 0925   | 1110 | 01       | 45   | Unit tripped due to low distribution oil pr.   |
| 2.     | 6.2.77              | 1120   | 2400 | 12       | 40   | Unit tripped to attend heavy leakage in H.P. injection line.                                 |
|        | 7.2.77              | 0000   | 0902 | 09       | 02   |  |
| 3.     | 26.2.77             | 2005   | 2400 | 03       | 55   | Unit stopped to attend leakage of boiler & turbine side.                                     |
|        | 27.2.77             | 0000   | 2400 | 24       | 00   |  |
|        | 28.2.77             | 0000   | 2400 | 24       | 00   |  |
| 4.     | 31.3.77             | 0442   | 2400 | 19       | 18   | Unit kept under planned shut down for turbine bearing inspection.                            |
|        | To<br>24.4.77       | 0000   | 0147 | 534      | 29   |  |
| 5.     | 10.5.77             | 1540   | 2400 | 08       | 20   | Unit tripped manually due to H.P.eccentricity being high.                                    |
|        | 11.5.77             | 0000   | 1002 | 10       | 02   |  |
| 6.     | 11.5.77             | 1022   | 1045 | 00       | 23   | Unit tripped manually as both interceptor valve closed.                                      |
| 7.     | 27.6.77             | 1512   | 1540 | 00       | 28   | Unit tripped on exhaust pressure high.   |
| 8.     | 13.7.77             | 2200   | 2400 | 02       | 00   | Unit tripped manually to attend the leakage on the flange of safety valve of B.D.valve line. |
|        | 14.7.77             | 0000   | 0132 | 01       | 32   |  |

|     |                |      |      |     |    |  |
|-----|----------------|------|------|-----|----|--|
| 9.  | 14.9.77        | 0825 | 2400 | 15  | 35 | Unit tripped manually<br>for attending to various<br>faults in boiler &<br>turbine.    |
|     | To<br>19.9.77  | 0000 | 1824 | 114 | 24 |  |
| 10. | 11.11.77       | 1628 | 2400 | 07  | 32 | Unit tripped manually<br>to attend to various<br>faults on boiler and<br>turbine side. |
|     | To<br>16.11.77 | 0000 | 2137 | 21  | 37 |  |
| 11. | 18.11.77       | 2353 | 2400 | 00  | 07 | Unit tripped manually<br>to attend the H.P.<br>radial bearing front<br>of turbine.     |
|     | 19.11.77       | 0000 | 2400 | 24  | 00 |  |
|     | 20.11.77       | 0000 | 0403 | 04  | 03 |  |
| 12. | 26.11.77       | 1130 | 1229 | 00  | 59 | Unit tripped on exhaust<br>pressure high.  |
| 13. | 26.11.77       | 1254 | 1433 | 01  | 39 | Unit tripped on exhaust<br>pressure high.  |
| 14. | 8.12.77        | 1700 | 2000 | 03  | 00 | Unit tripped due to<br>exhaust pressure high.  |
| 15. | 8.12.77        | 2312 | 2400 | 00  | 48 | Unit tripped due to<br>attend speeder gear.  |
|     | 9.12.77        | 0000 | 1638 | 16  | 38 |  |
| 16. | 21.12.77       | 0935 | 2112 | 11  | 35 | Unit tripped manually<br>to attend leakage in the<br>deacration line of MOP.           |
| 17. | 12.1.78        | 1040 | 2400 | 13  | 20 | Unit tripped manually<br>to attend leakage of<br>B.D.valve.                            |
|     | 13.1.78        | 0000 | 2400 | 24  | 00 |  |
|     | 14.1.78        | 0000 | 2400 | 24  | 00 |  |
|     | 15.1.78        | 0000 | 0258 | 02  | 58 |  |

|     |         |      |      |    |    |   |
|-----|---------|------|------|----|----|---|
| 18. | 15.1.78 | 0310 | 0332 | 00 | 22 | Unit tripped on hydro-mechanical trip.                      |
| 19. | 24.2.78 | 0917 | 1010 | 00 | 53 | Unit tripped on exhaust pressure high.                      |
| 20. | 24.2.78 | 1025 | 2400 | 13 | 35 | Unit tripped manually                                       |
|     | 25.2.78 | 0000 | 2400 | 24 | 00 | due to high differential                                    |
|     | 26.2.78 | 0000 | 1634 | 16 | 34 | tial expansions.  |
| 21. | 1.3.78  | 1302 | 1325 | 00 | 23 | Unit tripped due to low vacuum.                             |
| 22. | 9.3.78  | 1820 | 2400 | 05 | 40 | Unit tripped due to   |
|     | 10.3.78 | 0000 | 1632 | 16 | 32 | bursting of injection line of B.F.-2.                       |
| 23. | 25.3.78 | 0605 | 1728 | 11 | 23 | Unit tripped due to L.P. rotor differential expansion high. |
| 24. | 28.4.78 | 2303 | 2400 | 00 | 57 | Unit tripped manually                                       |
|     | 29.4.78 | 0000 | 0327 | 03 | 27 | to attend fault on T-G side.                                |
| 25. | 23.6.78 | 2139 | 2400 | 02 | 21 | Unit tripped manually                                       |
|     | 24.6.78 | 0000 | 1308 | 13 | 08 | due to H.P. rotor differential expansion high.              |
| 26. | 27.7.78 | 0738 | 2400 | 16 | 22 | Unit tripped by tripping                                    |
|     | To      |      |      |    |    | TTX.  |
|     | 31.7.78 | 0000 | 2145 | 94 | 45 |   |
| 27. | 31.7.78 | 2155 | 2400 | 02 | 05 | Unit tripped due to exhaust pressure high.                  |

|     |         |      |      |     |    |   |
|-----|---------|------|------|-----|----|---|
| 28. | 18.8.78 | 0909 | 0925 | 00  | 16 | Unit tripped on distribution oil pr. low.     |
| 29. | 20.8.78 | 1814 | 1953 | 01  | 41 | Unit tripped due to exhaust pr. high.         |
| 30. | 20.8.78 | 2005 | 2045 | 00  | 40 | Unit tripped due to distribution oil pr. low. |
| 31. | 14.9.78 | 0546 | 0602 | 00  | 16 | Unit tripped due to distribution oil pr. low. |
| 32. | 18.9.78 | 1413 | 1430 | 00  | 17 | Unit tripped due to distribution oil pr. low. |
| 33. | 19.9.78 | 1700 | 2400 | 07  | 00 | Unit tripped due to fire on turbine.          |
|     | To      |      |      |     |    |   |
|     | 4.10.78 | 0000 | 0958 | 345 | 58 |   |
| 34. | 4.10.78 | 1005 | 1125 | 01  | 20 | Unit tripped on hydro-mechanical trip.        |



TABLE VI

BREAK DOWN TIME OF THE TURBINE AUXILIARIES

| S. No. | Date, Month & Year | Period |      | Duration |      | Reasons   |
|--------|--------------------|--------|------|----------|------|---|
|        |                    | From   | To   | Hrs.     | Min. |   |
| 1.     | 22.9.77            | 0812   | 1030 | 02       | 18   | Unit tripped manually due to tripping of BFP on balancing leak off pressure high. |
| 2.     | 27.9.77            | 1520   | 2017 | 04       | 57   | Unit tripped due to the tripping of both CW pumps on condenser pr. high.          |
| 3.     | 27.9.77            | 2330   | 2400 | 00       | 30   | Unit tripped due to the tripping of both C.W. pumps on condenser pr. high.        |
|        | 28.9.77            | 0000   | 0423 | 04       | 23   |   |
| 4.     | 17.10.77           | 1023   | 1332 | 03       | 09   | Unit tripped manually through MFT as both C.W. pumps has tripped.                 |
| 5.     | 11.11.77           | 1628   | 2400 | 07       | 32   | Unit tripped manually to attend various faults on boiler & turbine side.          |
|        | To<br>16.11.77     | 0000   | 2137 | 117      | 37   |   |
| 6.     | 4.3.78             | 0230   | 1316 | 10       | 46   | Unit tripped manually to clean the BFP suction strainer.                          |
| 7.     | 8.4.78             | 1515   | 1632 | 01       | 17   | Unit tripped manually due to tripping of BFP.                                     |

|     |         |      |      |    |    |   |
|-----|---------|------|------|----|----|---|
| 8.  | 8.5.78  | 0850 | 1026 | 01 | 36 | Unit tripped on B.F.P.<br>tripped on over current<br>Y- phase.          |
| 9.  | 23.5.78 | 2005 | 2050 | 00 | 45 | Unit tripped manually<br>as vaccum was falling<br>due to low reheat pr. |
| 10. | 23.5.78 | 2235 | 2400 | 01 | 25 | Unit tripped manually<br>as vaccum was falling<br>due to low reheat pr. |
| 11. | 29.8.78 | 0115 | 1335 | 12 | 20 | Unit tripped due to<br>leakage in the discharge<br>line of B.F.P.       |



TABLE VII

BREAK DOWN TIME OF THE GENERATOR/EXCITER

| S. No. | Date, month & Year | Period |      | Duration |      | Reasons   |
|--------|--------------------|--------|------|----------|------|---|
|        |                    | From   | To   | Hrs.     | Min. |   |
| 1.     | 25.1.77            | 1115   | 1207 | 00       | 52   | Unit tripped on rotor earth fault.                          |
| 2.     | 6.2.77             | 0012   | 0044 | 00       | 32   | Unit tripped on reverse power.                              |
| 3.     | 6.3.77             | 1004   | 1023 | 00       | 19   | Unit tripped manually to clean slip rings of exciter.       |
| 4.     | 21.3.77            | 1243   | 1328 | 00       | 45   | Unit tripped manually to clean exciter brushes.             |
| 5.     | 21.3.77            | 1337   | 1730 | 03       | 53   | Unit tripped on rotor earth fault.                          |
| 6.     | 15.5.77            | 0120   | 0527 | 04       | 07   | Unit tripped on rotor earth fault.                          |
| 7.     | 12.10.77           | 1636   | 1812 | 01       | 36   | Unit tripped due to generator field earth fault.            |
| 8.     | 13.10.77           | 0927   | 2400 | 14       | 33   | Unit tripped due to system disturbance & rotor earth fault. |
| 9.     | 7.12.77            | 2108   | 2205 | 00       | 57   | Unit desynchronized cleaning exciter brushes.               |
| 10.    | 19.12.77           | 0837   | 1037 | 02       | 00   | Unit tripped on rotor earth fault.                          |



TABLE VIIIBREAK DOWN TIME OF THE ELECTRICAL EQUIPMENT

| S. No. | Date, Month & Year | Period |      | Duration |      | Reasons  |
|--------|--------------------|--------|------|----------|------|--|
|        |                    | From   | To   | Hrs.     | Min. |  |
| 1.     | 16.2.77            | 1817   | 1838 | 00       | 21   | Unit tripped on axial shift high due to load throw off.  |
| 2.     | 15.3.77            | 2107   | 2145 | 0038     | 38   | Unit tripped as the generator breaker opened.  |
| 3.     | 20.5.77            | 1012   | 1220 | 02       | 08   | Unit desynchronized.   |
| 4.     | 23.5.77            | 1832   | 2400 | 05       | 28   | Unit tripped due to operation of VAT Buckholz's relay.   |
|        | 24.5.77            | 0000   | 2400 | 24       | 00   |  |
|        | 25.5.77            | 0000   | 2400 | 24       | 00   |  |
|        | 26.5.77            | 0000   | 1426 | 14       | 26   |  |
| 5.     | 21.9.77            | 0730   | 2400 | 16       | 30   | Unit tripped manually as instruments supply failed due to tripping of station transformer on its fire protection air pressure low. |
|        | 22.9.77            | 0000   | 0431 | 04       | 31   |  |
| 6.     | 15.12.77           | 2300   | 2400 | 01       | 00   | Unit tripped due to tripping of all auxiliaries on under voltage.  |
|        | 16.12.77           | 0000   | 0305 | 03       | 05   |  |
| 7.     | 10.4.77            | 0427   | 0610 | 01       | 43   | Unit tripped due to the tripping of auto T/F on over load.   |
| 8.     | 12.9.78            | 0901   | 2400 | 14       | 59   | Unit tripped due to flash on BFP Motor.  |
|        | To<br>14.9.78      | 0000   | 0440 | 28       | 30   |  |



TABLE IX

BREAK-DOWN TIME OF THE INSTRUMENTS/CONTROLS

| S. No. | Date, Month & Year     | Period       |              | Duration |          | Reasons  |
|--------|------------------------|--------------|--------------|----------|----------|--|
|        |                        | From         | To           | Hrs.     | Min.     |  |
| 1.     | 6.1.77                 | 1600         | 1630         | 00       | 30       | Unit tripped on axial shift.                                     |
| 2.     | 6.1.77<br>To<br>9.1.77 | 1710<br>0000 | 2400<br>2028 | 06<br>68 | 50<br>28 | Unit tripped to check up axial shift.                            |
| 3.     | 19.1.77                | 1145         | 1306         | 01       | 21       | Unit tripped due to mal operation of TTX relay.                  |
| 4.     | 22.1.77                | 1757         | 1808         | 00       | 11       | Unit tripped due to high axial shift.                            |
| 5.     | 23.2.77                | 1220         | 1230         | 00       | 10       | Unit tripped on high axial shift.                                |
| 6.     | 25.2.77                | 0905         | 0955         | 00       | 50       | Unit tripped on high axial shift.                                |
| 7.     | 10.3.77<br>11.3.77     | 1942<br>0000 | 2400<br>0724 | 04<br>07 | 18<br>24 | Unit tripped due to burning of furnace draft cables.             |
| 8.     | 2.3.77<br>To<br>3.3.77 | 1055<br>0000 | 2400<br>1614 | 13<br>16 | 05<br>14 | Unit tripped without any initiating cause.                       |
| 9.     | 25.4.77                | 0534         | 0605         | 00       | 31       | Unit tripped due to thrust bearing failure hydromechanical trip. |

|     |          |      |      |    |    |  |
|-----|----------|------|------|----|----|--|
| 10. | 3.6.77   | 1630 | 1945 | 03 | 15 | Unit tripped due to thrust bearing failure hydromechanical trip.                 |
| 11. | 14.10.77 | 1103 | 1518 | 04 | 15 | Unit tripped due to the system disturbance and rotor earth fault.                |
| 12. | 26.2.78  | 1734 | 2400 | 06 | 26 | Unit tripped by tripping turbine.  |
|     | 27.2.78  | 0000 | 0034 | 00 | 34 |  |
| 13. | 11.4.78  | 2040 | 2400 | 03 | 20 | Unit tripped to attend leakage on the impulse line indicating pressure in B.P.E. |
|     | 12.4.78  | 0000 | 1542 | 15 | 42 |  |
| 14. | 27.5.78  | 0803 | 0829 | 00 | 26 | Unit tripped on thrust bearing failure hydraulic trip.                           |
| 15. | 14.9.78  | 0500 | 0523 | 00 | 23 | Unit tripped on hydro-mechanical shift.  |
| 16. | 7.9.78   | 1535 | 1829 | 02 | 54 | Unit tripped on no coal.   |





3. CALCULATIONS AND RESULTS

3.1 CALCULATIONS FOR COMPONENT RELIABILITY

In order to work out the reliability of various components, total cumulated failure time of various components, have been evaluated from the data included in section 2.3, Tables II to IX. As the total operating time of the system is known & the total cumulated failure time of each component within the total operating time of the system has been evaluated, reliability of each component can be worked out.

Reliability of the Component =

= 1 - (Total cumulated failure time of the Component / Total operating time of the system)

Table X & XI given below present the reliability of boiler auxiliaries and various other components respectively.

TABLE X
RELIABILITY OF BOILER AUXILIARIES

Table with 5 columns: I.D. Fan 1, I.D. Fan 2, F.D. Fan 1, F.D. Fan 2, Others. Rows include Component Unreliability and Component Reliability with values ranging from 0.000033 to 0.999966.

$$\begin{aligned} \text{Sub-system Reliability} &= [ 1 - ( 1-R_1 ) ( 1-R_2 ) ] \times [ 1 - ( 1-R_3 ) ( 1-R_4 ) ] \times R_5 \\ &= 0.98961 \end{aligned}$$

TABLE XI

RELIABILITY OF INDIVIDUAL COMPONENTS

| S. No | Component            | Total Cummulated Failure Time of Components in Hrs | Total Operating Time of The System in Hrs | Reliability |
|-------|----------------------|--|---|-------------|
| 1.    | Fuel Oil System      | 25   | 15,041                                    | 0.99833     |
| 2.    | Boiler Aux.          | 37686  | 15,041                                    | 0.98961     |
| 3.    | Main Boiler          | 2,666  | 15,041                                    | 0.82275     |
| 4.    | Turbine Aux.         | 159  | 15,041                                    | 0.98942     |
| 5.    | Turbine              | 854  | 15,041                                    | 0.94322     |
| 6.    | Generator/Exciter    | 40   | 15,041                                    | 0.99734     |
| 7.    | Electrical Equipment | 142  | 15,041                                    | 0.99055     |
| 8.    | Instruments/Controls | 149  | 15,041                                    | 0.99009     |

3.2 CALCULATIONS FOR SYSTEM RELIABILITY

3.2.1 ASSUMPTIONS

(i) The functional entity of each component/sub-system is independent of the other i.e. failures are independent.

(ii) A system has two states only, good or bad.

### 3.2.2 SYSTEM RELIABILITY

Smith (5) has described that a series system is one in which all components are so interrelated that the entire system will fail if any of its components fail. It is gathered from the study of data given in Table I and the system-component relationship on functional basis that the entire system trips on account of any fault in any of the components. In line with the above definition of series system, the system-component relationship of the unit under consideration is essentially that of series type. The system reliability is therefore the product of reliabilities of the constituent components. Therefore,

$$R_s = R_{s_1} \times R_{s_2} \times R_{s_3} \times R_{s_4} \quad \text{---- (17)}$$

where;

$$R_{s_1} = R_{F.O} \times R_{E.E} \times R_{I/C}$$

$$R_{s_2} = R_{B.A} \times R_{E.E} \times R_{I/C} \times R_{M.B} \times R_{E.E} \times R_{I/C}$$

$$R_{s_3} = R_{T.A} \times R_{E.E} \times R_{I/C} \times R_T \times R_{E.E} \times R_{I/C}$$

$$R_{s_4} = R_{G/E} \times R_{E.E} \times R_{I/C}$$

Taking values for reliability of various sub-systems from Table XI & putting these in equation (17) ,

$$R_s = 0.97909 \times 0.78311 \times 0.89761 \times 0.97812$$

$$R_s = 0.67317 \text{ i.e. } 67.317\%$$



5. SCOPE FOR FURTHER  
WORK

Having determined the reliability values for each sub-system as well as the system reliability it was possible to establish the weak links or less reliable Sub-systems. Thus various steps can be adopted to improve the system reliability. Some of the areas in which further work shall help in achieving our objective are enumerated below:

1. PREVENTIVE MAINTENANCE

From the failure time distribution of main boiler, turbine, boiler auxillaries & turbine auxillaries, a detailed preventive maintenance programme can be drawn up for a more efficient management of the thermal power plant.

2. DESIGN MODIFICATIONS

From the computed results for individual Sub-systems/components reliabilities, it is clear that the main boiler is the weakest link in the thermal power plant system. This warrants a more rigorous and accurate approach for its design & manufacture. A higher system reliability can be achieved by improvements/modifications in the existing designs of its various components. The extra expenditure incurred in research & development suggesting design modifications is likily to be compensated by achieving a higher system reliability & consequently less break downs.



REFERENCES

1. SMITH.D.J. BSc. " Reliability Engineering" Pitman Publishing, 1972.
2. GUPTA S.C. & KAPOOR V.K. " Fundamentals of Mathematical Statistics" - Sultan Chand & Sons, New Delhi- Sixth Edition- 1978.
3. SHOOMAN. MARTIN.L. " Probabilistic Reliability- An Engineering Approach- Mc Graw - Hill Book Company, New York.
4. SMITH. CHARLES.O."Introduction to Reliability in Design. Mc Graw-Hill, Inc-1976.
5. HAVILAND.R.P. "Engineering Reliability and long life Design. D.Van Nostrand company, Inc- Princeton, New Jersey.
6. GUHAIT.B, BANERJEE.R.N. & DUTTA. S. " Computer Aided Reliability Analyses of Equipment of Thermal Power Plant- Journal of the Institution of Engineers (India), Mechanical Engineering Division, Volume 61, Part ME, July 1980 UDC. 620.4
7. PATHARKAR.N.V. " Optimal Maintenance Strategies for Unreliable Systems- University of Roorkee- Roorkee.
8. KOHLI.J.C, SHARMA.J. & DAVE.M.P. " Scheduling in Power Systems- Models & Technique of Analysis.
9. DOLEZAL RICHARD & VAROP LUDVIK - PROCESS DYNAMICS, Automatic Control of Steam Generation Plant, Elsevier Publishing Company Limited- Amsterdam - London- New York.
10. KUMAR . SATISH." A Reliability Study of Guru Nanak Dev Thermal Plant, Bhatinda. Submitted for publication to the Institution of Engineers ( India ).






FIG.1. BATHTUB CURVE; FAILURE RATE VERSUS AGE




FIG.2 PROBABILITY DENSITY FUNCTION






FIG.3 THEORETICAL NON-REPLACE-  
MENT TEST



A



B

FIG. 4 SERIES RELIABILITY CONFIGURATION  
A. RELIABILITY BLOCK DIAGRAM,  
B. RELIABILITY GRAPH.






FIG.5. PARALLEL RELIABILITY CONFIGURATION  
A. BLOCK DIAGRAM  
B. RELIABILITY GRAPH



A

B

FIG. 6(A,B) COMBINED SERIES-PARALLEL CONFIGURATION  
A. SERIES-PARALLEL  
B. PARALLEL-SERIES




FIG.7. FUNCTIONAL BLOCK DIAGRAM




FIG-8(A). SUB-SYSTEM (S<sub>1</sub>)




FIG-8(B). SUB-SYSTEM (S<sub>2</sub>)




FIG-8(C). SUB-SYSTEM (S<sub>3</sub>)




FIG-8(D). SUB-SYSTEM (S<sub>4</sub>)

FIG-8(A,B,C,D) RELIABILITY BLOCK OF THE VARIOUS SUB-SYSTEM




FIG.9 RELIABILITY BLOCK DIAGRAM OF BOILER AUXILLARIES




FIG.10 RELIABILITY BLOCK DIAGRAM OF THE SYSTEM

APPENDIX I

Fig. 3 represents a general case of number of articles surviving at any time plotted against time. Take a small interval of time  $t$  to  $t + dt$ , during which the number surviving changes by  $d N_s(t)$ , we can say that  $d N_s(t)$  failures have occurred in time  $dt$ . As is evident from Fig.3,  $N_s(t)$  is a decreasing quantity, and hence  $d N_s(t)$  is negative. The failure rate at time  $t$ , in other words the instantaneous failure rate, is given by

$$\lambda(t) = - \frac{d N_s(t)}{N_s(t) dt}$$

Multiplying numerator and denominator by  $N_0$ ,

$$\lambda(t) = - \frac{d N_s(t)}{N_s(t) dt} \frac{N_0}{N_0}$$

or, rearranging,

$$\lambda(t) = - \frac{d N_s(t)}{N_0} \frac{N_0}{N_s(t)} \frac{1}{dt}$$

Since  $R(t) = N_s(t) / N_0$

$$\lambda(t) = - d R(t) \frac{1}{R(t)} \frac{1}{dt}$$

Therefore

$$-\lambda(t) dt = \frac{d R(t)}{R(t)}$$

Therefore,

$$-\int_0^t \lambda(t) dt = \frac{d R(t)}{R(t)}$$

$\lambda(t)$  is integrated with respect to time from 0 to  $t$ .  $1/R(t)$ , however, is being integrated with respect to  $R(t)$ . Now, when  $t = 0$ ,  $R(t) = 1$  ( the probability of not

not failing in no time is, ofcourse, 1 ). At time t the reliability is R (t) by definition.

Integrating, then,

$$\begin{aligned} - \int_0^t \lambda (t) dt &= \log_e R (t) \Big|_1^{R(t)} \\ &= \log_e R (t) - \log_e 1 \\ &= \log_e R (t) \end{aligned}$$

But if  $a = e^b$  then  $b = \log_e a$ , so that

$$R (t), \exp \left| - \int_0^t \lambda (t) dt \right|$$

If the failure rate is assumed not to vary with time, then

$\lambda (t) = \lambda$ ; therefore

$$R (t) = \exp \left| - \int_0^t \lambda dt \right|$$

But  $\int_0^t \lambda dt = \lambda t \Big|_0^t = \lambda t$

Therefore

$$R (t) = e^{-\lambda t}$$



APPENDIX II

Consider Fig. 2. The probability of failure in the interval  $t_1$  to  $t_2$  is  $\int_{t_1}^{t_2} f(t) dt$ .

The probability of failure in the interval from zero to  $t$  is the unreliability, given by

$$Q(t) = \int_0^t f(t) dt$$

Since the probability of failure between zero and infinity is unity, we can say that

$$\int_0^{\infty} f(t) dt = 1$$

Since  $R(t) = 1 - Q(t)$

$$R(t) = \int_0^{\infty} f(t) dt - \int_0^t f(t) dt = \int_t^{\infty} f(t) dt$$

Differentiating both sides of this equation, -

$$-dR(t) = f(t) dt \text{ so that } f(t) = -\frac{dR(t)}{dt}$$

Applying this to the constant failure rate,

$$f(t) = -\frac{d e^{-\lambda t}}{dt} = \lambda e^{-\lambda t} = \lambda R(t)$$

where  $R(t) = e^{-\lambda t}$  --- SEE APPENDIX I

Not constraining ourselves to the constant-failure-rate case, we have

$$f(t) = \frac{-de^{-\int_0^t \lambda(t) dt}}{dt} = \lambda(t) e^{-\int_0^t \lambda(t) dt} = \lambda(t) R(t)$$

Therefore

$$\lambda(t) = \frac{f(t)}{R(t)}$$

which always holds true. However,

$$f(t) = -\frac{dR(t)}{dt}$$

Therefore

$$\lambda(t) = -\frac{dR(t)}{R(t)dt}$$

This yields a general expression for failure rate in terms of reliability and is useful when failure rate cannot be derived from M.T.B.F. except when failure rate is constant.



APPENDIX III

Reliability function in case of the variation of failure rate with time takes the form, given by

$$R(t) = \exp \left[ - \left( \frac{t - \gamma}{\eta} \right)^\beta \right]$$

As can be seen from the above expression, the reliability function requires three parameters ( $\gamma, \beta, \eta$ ) in the Weibull case.

Therefore

$$1 - Q(t) = \exp \left[ - \left( \frac{t - \gamma}{\eta} \right)^\beta \right]$$

So that

$$\frac{1}{1 - Q(t)} = \exp \left[ - \left( \frac{t - \gamma}{\eta} \right)^\beta \right]$$

Whence

$$\log \frac{1}{1 - Q(t)} = \left( \frac{t - \gamma}{\eta} \right)^\beta$$

and

$$\log \log \frac{1}{1 - Q(t)} = \beta \log (t - \gamma) - \beta \log \eta$$

Replacing  $(t - \gamma)$  by  $t'$ ,

$$\log \log \frac{1}{1 - Q(t)} = \beta \log t' - \beta \log \eta$$

but if

$$\log \log \frac{1}{1 - Q(t)} = 0$$

then  $\beta \log t' = \beta \log \eta$

so that

$$t' = \eta$$

This occurs if

$$\log \log \frac{1}{1 - Q(t)} = 0 \text{ so that } \log \frac{1}{1 - Q(t)} = 1$$

i.e.  $\frac{1}{1-Q(t)} = e$  and  $Q(t) = 0.63$

Assuming then that  $\gamma = 0$  &  $t' = t$ , then

$$\log \log \frac{1}{1-Q(t)} = \beta \log t - \beta \log \eta$$

which is the equation of a straight line of the form

$$y = mx + c, \text{ where}$$

$$y = \log \log \frac{1}{1-Q(t)}, \quad x = \log t$$

and the slope is  $\beta$ .

If the group of failures are distributed according to the Weibull function and it is assumed that  $\gamma = 0$ , then by plotting these failures against time on double logarithmic paper ( failure percentage on log log scale & time on log scale), a straight line should be obtained. The Weibull parameters, and hence the expression for reliability, may then be obtained by suitable measurements of slope, etc.

LIBRARY  
THAPAR UNIVERSITY, PATIALA.  
JOURNAL NO. 13026

~~13026~~

Thapar University, Patiala  
Central Library



90207